

SUBMIT BIDS TO:	CITY OF TUSCALOOSA P.O. BOX 2089 TUSCALOOSA, AL 35403	PURCHASING OFFICE 2201 UNIV. BLVD. TUSCALOOSA, AL 35401	INVITATION TO BID										
BID TITLE VARIOUS INFRASTRUCTURE SUPPLIES			BID NO. 9070-083021-1										
PAGE 1 OF 45 PAGES	BIDS WILL BE OPENED AT 2:00 PM ON AUGUST 30, 2021 IN THE OFFICE OF THE PURCHASING AGENT, 2201 UNIVERSITY BLVD. TUSCALOOSA, AL 35401 AND MAY NOT BE WITHDRAWN FOR THIRTY (30) DAYS AFTER SUCH DATE & TIME.		ISSUE DATE 07/28/2021										
 <p style="text-align: center;"><u>MAYOR</u> WALT MADDOX</p> <p style="text-align: center;"><u>COUNCIL MEMBERS</u></p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">MATTHEW WILSON</td> <td style="width: 50%;">KIP TYNER</td> </tr> <tr> <td>RAEVAN HOWARD</td> <td>JOHN FAILE</td> </tr> <tr> <td>NORMAN CROW</td> <td>VACANT</td> </tr> <tr> <td>LEE BUSBY</td> <td></td> </tr> </table> <p style="text-align: center;"><u>PURCHASING AGENT</u> AMANDA GANN</p>		MATTHEW WILSON	KIP TYNER	RAEVAN HOWARD	JOHN FAILE	NORMAN CROW	VACANT	LEE BUSBY		Vendor Information (SECTION TO BE COMPLETED BY VENDOR) <hr/> Company Name (Please Print) <hr/> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Phone Number</td> <td style="width: 50%;">Fax Number</td> </tr> </table> <hr/> Email Address		Phone Number	Fax Number
MATTHEW WILSON	KIP TYNER												
RAEVAN HOWARD	JOHN FAILE												
NORMAN CROW	VACANT												
LEE BUSBY													
Phone Number	Fax Number												

GENERAL CONDITIONS OF INVITATIONS TO BID

1. PREPARATION OF BIDS

Bids will be prepared in accordance with the following:

- (a) Our enclosed Bid forms are to be used in submitting your bid.
- (b) All information required by the Bid form shall be furnished. The bidder shall print or type his name and manually sign the schedule and each continuation sheet on which any entry is made.
- (c) Unit prices shall be shown and where there is an error in extension of price, the unit price shall govern.
- (d) Proposed delivery time must be shown and shall include Sundays and holidays.
- (e) Bidder will not include federal taxes nor State of Alabama sales, excise, and use taxes in bid prices as the City is exempt from payment of such taxes. An exemption certificate will be signed where applicable upon request.
- (f) Bidders shall thoroughly examine the drawings, specifications, schedule, instructions and all other contract documents.
- (g) Bidders shall make all investigations necessary to thoroughly inform themselves regarding plant and facilities for delivery of material and equipment as required by the bid conditions. No plea of ignorance by the bidder of conditions that exist or that may hereafter exist as a result of failure or omission on the part of the bidder to make the necessary examinations and investigations, or failure to fulfill in every detail the requirements of the contract documents, will be accepted as a basis for varying the requirements of the City or the compensation to the vendor.
- (h) Bidders are advised that all City Contracts are subject to all legal requirements provided for in the Purchasing ordinance and/or State and Federal Statutes.

2. DESCRIPTION OF SUPPLIES

- (a) Any manufacturer's names, trade names, brand name, or catalog numbers used in specifications are for the purpose of describing and establishing general quality levels. SUCH REFERENCES ARE NOT INTENDED TO BE RESTRICTIVE. Bids will be considered for any brand which meets the quality of the specifications listed for any items.
- (b) Bidders are required to state exactly what they intend to furnish, otherwise they shall be required to furnish the items as specified.
- (c) Bidders will submit, with their proposal, data necessary to evaluate and determine the quality of the item(s) they are bidding.

3. SUBMISSION OF BIDS

- (a) Bids and changes thereto shall be enclosed in sealed envelopes addressed to Amanda Gann, Purchasing Agent, 2201 University Blvd., Tuscaloosa, Alabama 35401. The name and address of the bidder, the date and hour of the bid opening and the material or service bid on shall be placed on the outside of the envelope.
- (b) Bids must be submitted on the forms furnished. Telegraphic bids will not be considered.

4. REJECTION OF BIDS

- (a) The City may reject a bid if:
 - 1. The bidder misstates or conceals any material fact in the bid, or if,
 - 2. The bid does not strictly conform to the law or requirement of bid, or if,
 - 3. The bid is conditional, except that the bidder may qualify his bid for acceptance by the City on an "all or none" basis, or a "low item" basis. An "all or none" basis bid must include all items upon which bids are invited.
- (b) The City may, however, reject all bids whenever it is deemed in the best interest of the City. The City may also waive any minor informalities or irregularities in any bid.

5. WITHDRAWAL OF BIDS

BID NO. 9070-083021-1

Signature _____

- (a) Bids may not be withdrawn after the time set for the bid opening for a period of time as specified.
- (b) Bids may be withdrawn prior to the time set for the bid opening.
- 6. LATE BIDS OR MODIFICATIONS**
- (a) Bids and modifications received after the time set for the bid opening will not be considered.
- (b) Modifications in writing received prior to the time set for the bid opening will be accepted.
- 7. CLARIFICATIONS OR OBJECTION TO BID SPECIFICATIONS**
- If any person contemplating submitting a bid for this contract is in doubt as to the true meaning of the specifications or other bid documents of any part thereof, he may submit to the Purchasing Agent on or before five (5) days prior to scheduled opening a request for clarification. All such requests for information shall be made in writing and the person submitting the request will be responsible for its prompt delivery. Any objection to the specifications and requirements as set forth in this bid must be filed in writing with the Purchasing Agent on or before five (5) days prior to scheduled opening.
- 8. DISCOUNTS**
- (a) Bidders may offer a cash discount for prompt payment; however, such discounts shall NOT be considered in determining the lowest net cost for bid evaluation purposes. Bidders are encouraged to reflect cash discounts in the unit prices quoted.
- (b) In connection with any discount offered, time will be computed from the date of receipt of supplies or services or from the date a correct invoice is received, whichever is the later date. Payment is deemed to be made on the date of mailing of the check.
- 9. SAMPLES**
- Samples, when required, must be submitted within the time specified at no expense to the City of Tuscaloosa. If not destroyed or used up during testing, samples will be returned upon request at the bidder's expense, unless stated otherwise in Special Conditions or Specifications. Each individual sample must be labeled with bidder's name and manufacturer's brand name and number.
- 10. AWARD OF CONTRACT**
- (a) The contract will be awarded to the lowest responsible bidder based upon the following factors: quality; conformity with specifications; purpose for which required; terms of delivery; transportation charges; dates of delivery.
- (b) The city reserves the right to accept and award item by item, and/or by group, or in the aggregate, unless the bidder qualifies his bid by specified limitations. Re Par.4(a)3.
- (c) If two or more bids received are for the same total amount or unit price, quality and service being equal, the contract shall be awarded to a local bidder.
- (d) Prices quoted must be FOB Destination to Tuscaloosa with all transportation charges prepaid unless otherwise specified in the Invitation to Bid.
- (e) A written award of acceptance (Purchase Order), mailed or otherwise furnished to the successful bidder shall result in a binding contract.
- 11. DELIVERY**
- (a) Deliveries are to be FOB Destination unless otherwise specified in the Invitation to Bids.
- (b) Deliveries are to be made during regular business hours.
- 12. CONDITION OF MATERIALS AND PACKAGING**
- All items furnished must be new and free from defects. No others will be accepted under the terms and intent of this bid. All containers shall be new and suitable for storage or shipment, and price bid shall include standard commercial packaging.
- 13. CLAIMS**
- Successful bidder(s) will be responsible for making any and all claims against carriers for missing or damaged items.
- 14. LOCAL, STATE, AND FEDERAL COMPLIANCE REQUIREMENTS**
- Bidders shall comply with all local, state, and federal directives, orders and laws as applicable to this bid and subsequent contract(s).
- 15. PROVISION FOR OTHER AGENCIES**
- Unless otherwise stipulated by the bidder, the bidder agrees when submitting his bid to make available to all City agencies, departments, and in-city municipalities the bid prices he submits, in accordance with the bid terms and conditions, should any said department, agency, or municipality wish to buy under this proposal.
- 16. COLLUSION**
- The bidder, by affixing his signature to this proposal, agrees to the following: "Bidder certifies that his bid is made without previous understanding, agreement, or connection with any person, firm, or corporation making a bid for the same items and is in all respects fair, without outside control, collusion, fraud, or otherwise illegal action".
- 17. VARIANCE IN CONDITIONS**
- Any and all special conditions and specifications attached hereto which vary from General Conditions shall have precedence.
- 18. MINORITY / DISADVANTAGED BUSINESS ENTERPRISE PROGRAM**
- The City of Tuscaloosa has voluntarily adopted a Minority / Disadvantaged Business Enterprise ("MBE/DBE/WBE") Program called Tuscaloosa Builds, which is designed to encourage the participation and development of minority and disadvantaged business enterprises and to promote equal business opportunities to the fullest extent allowed by state and federal law. To learn more about this program, visit the City's website at www.tuscaloosa.com.

SPECIAL CONDITIONS

The General Conditions of Invitations to Bid and any Special Conditions stated shall be considered as part of the specifications of the bid.

Reference to brand names and numbers is descriptive, but not restrictive, unless otherwise specified. Bids on equivalent items meeting the standards of quality thereby indicated will be considered, providing the bid clearly describes the article offered and indicates how it differs from the referenced brands. Descriptive literature and manufacturer's specifications plus any supplemental information necessary for comparison purposes must be submitted with the bid or the bid on that item will be rejected. Reference to literature submitted with a previous bid or on file with the Division of Purchasing will not satisfy this requirement. The burden is on the bidder to demonstrate that the item bid is equivalent to the item specified in the ITB. Any exceptions taken to any item(s) must be fully explained in written detail on bidders' letterhead and attached to the bid when submitted.

Awards shall be made or contracts entered into with the lowest responsible bidder(s) meeting all specifications and terms and conditions established by the Division of Purchasing. The Division of Purchasing reserves the right to determine the lowest responsible bidder on the basis of an individual item or group of items. Delivery dates may be a factor in awards. Local Bidder Preference will be used in bid evaluation in accordance with State of Alabama Bid Law Section 41-16-50(a).

The issuance of a City of Tuscaloosa Purchase Order or Purchasing Card is required to constitute a contract between the vendor and the City of Tuscaloosa, which shall bind the vendor to furnish and deliver the commodities and/or services ordered at the prices, terms, and conditions quoted.

Questions concerning the bid process should be directed to Amanda Gann at (205) 248-5173 or agann@tuscaloosa.com (e-mail is preferred). Questions concerning Specifications should be directed to Hunter McJenkin at (205) 248-5953 or hmcjenkin@tuscaloosa.com.

Any addendums issued for this bid will be posted on the City Of Tuscaloosa website at <http://www.tuscaloosa.com/bids>. It is the responsibility of the bidder to check this page for any addendums before submitting their bid.

Vendor to submit the following:

- Signed Special Conditions page
- Any necessary descriptive literature and/or specifications information as outlined above and/or elsewhere in this document
- Completed and signed Contract Information page
- Completed and signed Bid Submissions Work Sheets
- Completed and signed Bidder's Response Form

NOTE: Sheet(s) submitted without Company Name & Signature WILL NOT be considered for bid award.

VENDOR MUST SUBMIT AN ORIGINAL BID AND ONE COMPLETE COPY OR THE BID MAY BE REJECTED.

Bid submissions shall be submitted in a sealed envelope and addressed to: Amanda Gann, Purchasing Agent, 2201 University Blvd., Tuscaloosa, AL 35401. The name and address of the bidder, the date and hour of the bid opening and the Bid Title shall be placed on the outside of the envelope.

Failure to properly address and label sealed envelope may result in bid rejection.

IMPORTANT COVID-19 INFORMATION

Electronic Submissions

Submission of completed bid documents as .pdf documents can now be done at www.centralbidding.com. For any questions about the electronic bid document submission process, please contact City of Tuscaloosa Purchasing or Central Bidding at 225-810-4814 or support@centralbidding.com.

Submitting Bids by Hand

Bidders submitting bids by hand must enter at the City Hall complex entrance located on the 4th level of the City's Intermodal Facility parking deck; the entrance to the deck is located on 7th Street beside Government Plaza. Bidders are to turn in bids to the security guard on duty at the desk. Security will notify Purchasing that a bid has been turned in.

Note: Masks/face coverings may be required for entry into certain areas inside City Hall.

Submitting Bids by Mail/Package Carrier

Bidders who submit bids by mail or package carriers are encouraged to do the following:

1. Correctly label the outer envelope as instructed on page 3-4 of this bid document to insure proper identification and delivery to Purchasing.
2. Use a shipping method that includes tracking information and an estimated delivery time. USPS standard mailing without tracking is not recommended.
3. Don't wait until the last minute. Allow at least a day's cushion in case deliveries are delayed unexpectedly.

Note: Keep in mind that the City is not responsible for deliveries from mail/package carriers that are delivered after the bid deadline.

Bid Opening & Potential Date Change

If bidders choose to attend the bid opening, only one representative per bidder will be allowed to attend. All attendees shall be healthy and display no symptoms of sickness. Social distancing of at least six (6) feet shall be maintained. Face coverings that fully cover the nose and mouth may be required while in certain areas of all City-owned/operated facilities.

Circumstances related to COVID-19 may warrant a change to the bid opening date. Any such date change will be published in an addendum and posted on our City's website at <https://www.tuscaloosa.com/bids>. Bidders are advised to check this web page for any addendums prior to submitting their bids.

Bid results will be posted on the Bids page of the City's website within 24 hours of bid opening. Link: <https://www.tuscaloosa.com/bids>

CONTRACT INFORMATION

The term of contracts resulting from this bid award shall be from October 1, 2021, or date of award if after that date, through September 30, 2022.

Bid items are grouped into schedules by product group/type. It is the City's intention to award this bid by schedule. In order to be considered for award of a schedule, bidder should submit a bid for all items in that schedule. However, the City reserves the right to make award by item or group of items if it is in the best interest of the City to do so.

The parts/supplies listed in the bid are the ones most commonly purchased by the City. If awarded a schedule, bidder(s) must agree to extend similar pricing/discounts for those same product types in sizes/models not specifically listed. For example, if awarded the schedule for Tap Sleeves, awarded bidder will sell Tap Sleeves in sizes not listed in the bid at the same price/discount levels as the sizes listed in the bid.

The City intends to award this bid to Primary Bidder(s). The City may also choose to make an award to a Secondary Bidder to be used in the event the Primary Bidder is unable to provide an item within a reasonable amount of time as determined by the City. The Secondary Bidder (if applicable) shall be obligated to all applicable terms and conditions contained herein. By submitting a bid, all bidders agree to become Secondary Bidder if determined as such by the City.

Awarded bidders not honoring bid prices for the entire contract period will have their bid award rescinded for the remainder of the awarded contract period.

The successful bidder shall guarantee full delivery within 30 days of receipt of order. If deliveries are not made at the time agreed upon, the City reserves the right to cancel and purchase from Secondary Bidder or the next lowest bidder, if applicable. Consistent failure to meet delivery times will constitute grounds for the termination of the awarded section of the contract. This declaration may result in the rejection of any future bids submitted by the vendor.

Bidders must include with their bid any descriptive literature and specifications information necessary for product evaluation. Determination as to whether an item submitted for bid meets specifications shall be the sole responsibility of City personnel. Failure to include this information will subject a bid to rejection.

All items will be ordered on an as needed basis. There are no minimum order guarantees and no estimates for expected annual purchases.

UNBALANCED BIDDING: The City will reject any bid that is unbalanced if it is in the best interest of the City to do so. A bid will be considered unbalanced when, in the opinion of the Purchasing Agent, the bid allocates a disproportionate share of costs to the price of one or more bid items in order to reduce the costs to the price of another bid item or items, and if there is a reasonable possibility that the bid will not result in the lowest overall cost to the City.

MATERIAL SPECIFICATIONS**Schedule 1****PIPE, COPPER**

All copper pipe must be equivalent to the following:

- Pipe to be seamless.
- Must conform to ASTM Specification B-88-62 "TYPE K SOFT"
- ¾" & 1" pipe must be in 60 foot rolls only.
- 2" pipe to be in 40 or 60 foot rolls as requested by purchaser.
- Price must be on a per foot basis.

PIPE, BRASS

All brass pipe must be equivalent to the following:

- Pipe to be seamless.
- Must conform to ASTM Specification B-43 Red Brass (Copper Alloy C230).
- Price must be on a per foot basis.

Schedule 2**PIPE, DUCTILE IRON**

4" thru 12" Ductile Iron Pipe will be Class 350.

14" and Larger Ductile Iron Pipe will be Class 250.

Compression type joint.

Pipe must meet requirements of ANSI, AWWA C151/A21.51, and Federal Specifications.

Plain end of pipe should be beveled.

Pipe must come complete with gaskets (ANSI, AWWA C151/A21.51) and joint lubricant.

Pipe is to be cement lined in accordance with Specifications ASA A21.4 (AWWA C104) and/or Federal Specifications WW-P-421B.

Pipe is to have a bituminous seal coat, NSF 61.

All pipe must be new and shall be manufactured in accordance with ANSI/AWWA C151/A21.51 in the United States of America (USA); all ductile iron pipe shall be cast, cleaned, lined, coated, tested, and certified at a manufacturing facility located in the USA.

The raw material for ductile iron shall have an average minimum content consisting of at least 90% or more recycled ferrous scrap iron and steel.

Bids must be on a price per linear foot basis.

PIPE TO BE ORDERED AS NEEDED.

APPROVED MANUFACTURERS

American Cast Iron Pipe Co.

U. S. Pipe

McWane Pipe

Approved Equal

Schedule 3

HDPE DRAINAGE PIPE

High-density polyethylene conforming to the minimum requirements of cell classification 435400C. Pipe should have smooth interior and annular exterior corrugations.

Schedule 4

GALVANIZED PIPE

Pipe is intended for mechanical and pressure applications.

Pipe is suitable for welding, threading, and grooving.

Produced to ASTM A53 / 53M.

Schedule 5

FIRE HYDRANT

Fire hydrants with M.J. Shoe and fire hydrants with Flanged Shoe will be bid.

All fire hydrants must have test pressure of 300 psig and working pressure of 175 psig.

All fire hydrants must have 4 1/2" valve opening.

All fire hydrants must have 3'0", 3'6", 4'0", 5'0" bury.

All fire hydrants must have two (2) 2 1/2 hose MOZ GA NS and One (1) 4 1/2" Pumper NOZ GA 4-556.

All fire hydrants must have 1 1/2" Pent open left operating nut (bronze).

All fire hydrants must have 6" M.J. or Flanged Shoe complete with gland and plain rubber gaskets.

All fire hydrants must comply with AWWA Specifications C-502.

All fire hydrants must be painted with fire hydrant red enameled paint completely.

All fire hydrants must be equipped with safety flange (break away traffic model).

All fire hydrants must be equipped with the following:

- Non-kinking chains on nozzle caps with rubber gasket seal or "O" ring seals.
- Double drain valves and double drain openings
- Bronze seat ring with compression type main valve
- Positive stop stem (eliminates over-travel of stem)

The hydrant main valve shall close with the pressure and all operating parts including the stem operating nut, hold down nut, valve top, drain ring, and seat shall be all-bronze.

Friction losses through the hydrant shall not exceed 5.0 psig at 1000 gpm through the pumper nozzle and 2.0 psig through two hose nozzles at 500 gpm, when simultaneously tested as outlined by AWWA C-502. Hydrants shall be such that easy installation of extensions can be accommodated either at the ground line or to connection, without shutting off the water.

All hydrants shall utilize integral cast flanges. The hydrant shall have a 6" inlet connection of the mechanical joint type, suitable for all classes of cast iron or ductile iron pipe, unless otherwise noted.

The bonnet assembly shall be one-piece and provided with an oil reservoir and lubrication system that automatically circulates lubricant to all threads and bearing surfaces each time the hydrant is operated. The system shall be completely sealed from the waterway and all external contaminants by two (2) O-ring stem seals and a weather shield attached directly to the operating nut. Hydrants shall be factory pre-filled with a lubricant suitable for a working temperature range of a -60 degree Fahrenheit to a +150 degree Fahrenheit.

The drain valve system shall be fully automatic and free of springs, toggles, or other devices, requiring field adjustment. Both the valve seat ring and drain ring shall have no less than two (2) openings that are forced-flushed during opening and closing cycles, but are sealed when the hydrant is fully open.

Hydrant shall have a three foot bury unless otherwise noted, with the painting and coating as prescribed in AWWA C-502, with the color painted red enamel above the ground line. The cast iron components below ground shall be asphalt varnish and subscribing to the current standards and practices.

Each proposal shall include an expanded view of the hydrant, which shows all parts and their proper locations. A price list of repair parts may be requested for review purposes.

APPROVED MANUFACTURERS AND MODELS

American Cast Iron Pipe Co.	Mark 73
Mueller Company	Centurion
M & H Valve Company	Model 129
Clow Valve Company	Medallion
U. S. Pipe Company	Metropolitan 250 M-94

Schedule 6

MANHOLE FRAME AND COVER

- MATERIAL:** Grey Iron castings shall conform to the requirements of AASHTO M 105 Class 35 B or ASTM A 48 Class 35 B, unless otherwise specified.
- MANUFACTURING:** Castings shall be manufactured true to pattern and component parts shall fit together in a satisfactory manner. They shall be smooth and well cleaned by shot blasting. Circular manhole rings, covers and grates shall be furnished with machined horizontal bearing surfaces unless otherwise specified.
- TOLERANCES:** As cast dimensions may vary by plus or minus 1/16 inch per foot in critical areas relating to fit, load bearing capacity and drainage openings. Non-critical dimensions may be modified slightly to facilitate proper casting techniques, without notice. Notwithstanding these tolerances, all rings, covers, frames, grates, and curb hoods of the same nominal size are interchangeable.
- WEIGHTS:** Casting weights are accurate, and shall be within plus or minus 5% of the specified weight.

BID NO. 9070-083021-1

Signature _____

NOTE: Frame and cover castings shall be clearly marked with the manufacturer’s name, product catalog number and Made in the USA in cast letters. All frame and covers shall meet the dimensions specified in standard details provided by the City.

APPROVED MANUFACTURERS AND MODELS

Vulcan Foundry No. V-1344-1

U.S. Foundry No. USF 420

Approved equal with City of Tuscaloosa Logo.

WATERTIGHT FRAME AND COVER

MATERIAL: Grey Iron castings shall conform to the requirements of AASHTO M 105 Class 35 B or ASTM A 48 Class 35 B, unless otherwise specified.

MANUFACTURING: Castings shall be manufactured true to pattern and component parts shall fit together in a satisfactory manner. They shall be smooth and well cleaned by shot blasting. Circular manhole rings, covers and grates shall be furnished with machined horizontal bearing surfaces unless otherwise specified.

TOLERANCES: As cast dimensions may vary by plus or minus 1/16 inch per foot in critical areas relating to fit, load bearing capacity and drainage openings. Non-critical dimensions may be modified slightly to facilitate proper casting techniques, without notice. Notwithstanding these tolerances, all rings, covers, frames, grates, and curb hoods of the same nominal size are interchangeable.

WEIGHTS: Casting weights are accurate, and shall be within plus or minus 5% of the specified weight.

NOTE: MANHOLE RIM AND COVER SHALL BE WATERTIGHT.

Frame and cover castings shall be clearly marked with the manufacturer’s name, product catalog number and Made in the USA in cast letters. All frame and covers shall meet the dimensions specified in standard details provided by the City.

Approx. weight of frame and cover – 350 lbs. minimum.

APPROVED MANUFACTURERS AND MODELS

East Jordan Iron Works No. V-2358

US Foundry No. 1452

Approved equal with City of Tuscaloosa Logo.

PRECAST CONCRETE MANHOLES

(1.) Precast concrete manholes shall be of reinforced concrete sections manufactured in accordance with ASTM C 478, latest revision. In addition, the fine aggregate used shall be natural silica sand. The concrete when tested in compression shall be not less than 4,000 psi and absorption shall not exceed 9%. Minimum wall thickness of the manhole riser sections shall be as follows:

I.D. Wall th.

48" 5"

60" 6"

72" 7"

84" 8"

96" 9"

Cone sections shall be made with minimum wall thicknesses of 5" at the bottom and 8" at the top. The minimum thickness of the bottom slab shall be 6" for all manhole diameters. Manhole diameters to be used shall be as indicated on the plans.

(2.) Joints between the manhole sections will be made with offset joints with rubber gaskets or preformed butyl sealants. Rubber gaskets shall meet the requirements of ASTM C 443, latest revision. Sealants shall meet ASTM C 990 and AASHTO M-198B.

(3.) Steel reinforcement shall conform to ASTM A-82 or A-185. The circumferential reinforcement may consist of either one or two lines of steel. The total steel area per vertical foot shall not be less than 0.0025 times the inside diameter in inches.

(4.) For purposes of handling and placement: The 48" diameter manholes shall have lift inserts which shall be cast in each section. Two lift holes shall be cast in sections larger than 48" in diameter.

(5.) Openings for inlet and discharge sewer pipes shall be provided in the manhole base section and in the riser section for drop-manholes. Openings shall be at positions and elevations as indicated on the plans or predetermined in the field, and may be cast into the manhole wall or mechanically cored on completed sections. Where pipes are to be sealed into the manhole wall with mortar, openings shall be large enough to permit such variations in both horizontal and vertical position as field conditions may dictate. Cored openings shall be sized to accommodate the flexible manhole sleeve specified for the project.

A.) Mortar for sealing pipes into manholes shall be a non-shrink or hydraulic cement grout.

B.) Flexible manhole connectors suitable for use in precast or cored openings utilizing pre-molded shapes positioned with expansion rings shall comply with the requirements of ASTM C 923. Flexible connectors shall be installed as recommended by the manufacturer.

(6.) Manhole steps shall be reinforced plastic step complying with the requirements of ASTM C 478.

APPROVED MANUFACTURERS

Hanson Pipe & Products

Sherman-Dixie Concrete Industries

Foley Products

Approved equal

Schedule 7

CURB STOPS

Curb valves shall be of the closed bottom design and sealed against external leakage at the top and port by utilizing non-adjustable resilient seals. Shut off shall be affected by a resilient pressure actuated seal placed in the key or plug as to completely enclose the inlet port flow way in the closed position. All curb valves shall have the open/closed positions controlled by check lugs which are integral parts of the key and the body. Curbs Stops shall be of a 300 psi rating.

Curb Stops shall have compression nut with gripper ring and gasket providing a water tight seal by compressing gasket around tubing and compressing the gripper ring providing high pull out resistance.

Compression nuts requiring a split type clamp with screw or bolt will not be accepted.

Valves for the respective installation (s) must have the following laying lengths to facilitate change-outs at a minimum of cost and time:

	SIZE	LENGTH (IN.)
FIP X FIP VALVES	3/4"	3.21" + or - 0.0625
	1"	3.96" + or - 0.0625
COMPRESSION X FIP	3/4"	.84" + or - 0.0625
	1"	4.35" + or - 0.0625

NOTE: ALL CURB VALVE OPENINGS SHALL BE FULL PORT OPENING.
(3/4" X 3/4" X 3/4") AND (1" X 1" X 1")

Curb Stops shall be Ball Valve type with Lock Wing.

METER COUPLINGS

All meter couplings shall be fully machined both inside and out, meeting ASTM B-62, with each component easily interchanging with all existing meters/meter couplings. Laying lengths shall be specified at time of ordering or the 2 1/2" length shall be supplied unless notified.

NOTE: Meter couplings to be full opening.
3/4" coupling to have 3/4" inside diameter opening.
1" coupling to have 1" inside diameter opening.

CORPORATION STOP

All components of the corporation stops shall be manufactured of certified ingot, conforming to AWWA C-800. The stem and retaining nut shall be so designed that failure from over-tightening of the nut results in thread stripping rather than stem fracture.

Corporation stops shall be of a 300 psi rating.

Corporation Stops shall have compression nut with gripper ring and gasket providing a water tight seal by compressing of gasket around tubing and compressing the gripper ring providing high pull out resistance.

Compression nuts requiring a split type clamp with screw or bolt will not be accepted.

Corporation stops shall be BALL VALVE type. ALL CORPORATION STOPS TO BE FULL PORT OPENINGS.

BACKFLOW PREVENTERS

All types, General Specifications

ALL BACKFLOW PREVENTERS 3" AND LARGER SHALL COME COMPLETE WITH RESILIENT SEAT (RS) GATE VALVES.

Shall have replaceable seats. Shall be serviceable in-line.
Backflow preventers shall consist of two independently operating, internally loaded check valves.

All Backflow Preventers/Check Valve assemblies shall conform to applicable sections of the ANSI/AWWA, ASSE and USC Foundation for Cross-Connection Control and Hydraulic Research.

DOUBLE CHECK VALVE BACKFLOW PREVENTER 2-1/2" – 12"

Double Check Valve Backflow Preventers shall conform to ANSI/AWWA C510, and ASSE 1015, latest revisions. All assemblies shall be approved by both ASSE and the University of Southern California Foundation for Cross-Connection Control and Hydraulic Research, and shall be supplied only in approved configurations, including shut-off valves.

Double Check Valve Backflow Preventers shall consist of two line-sized independently acting check valves, internally force loaded to a normal closed position, designed and constructed to operate under intermittent or continuous pressure conditions. Body shall be stainless steel and contain necessary test cocks.

Unless specified otherwise at the time of order, all assemblies shall be supplied with non-rising stem gate valves.

Approved Manufacturers/Models (or Part Numbers)

1. Ames Series 2000SS
2. Conbraco DCLF 4A
3. Watts 774
4. Wilkins 350AST

DOUBLE DETECTOR CHECK VALVE BACKFLOW PREVENTER 2-1/2" – 12"

Double Detector Check Valve Backflow Preventers shall conform ANSI/AWWA C510, and ASSE 1015 and 1048, latest revisions. All assemblies shall be approved by both ASSE and the University of Southern California Foundation for Cross- Connection Control and Hydraulic Research, and shall be supplied only in approved configurations, including shut-off valves.

The Double Detector Check Backflow Preventer shall be composed of a line-sized approved Double Check Backflow Preventer assembly with piping for a by-pass water meter and a meter-sized approved Double Check Backflow Preventer. All assemblies shall be supplied complete. By-pass meter will be a standard 5/8" x 3/4" meter. By-pass piping shall be constructed of brass and shall include properly spaced meter nut connections for insertion of water meter with no modifications. Assembly shall be designed such that by- pass meter shall register all low flow demands of 3 CF or less, with static pressure drop across by-pass assembly at least 2 psi less than static pressure drop across the line size assembly in order to assure accurate measurement of low flow demands. Check valves should be accessible from the top of the device for maintenance without removing the device from in-line. All assemblies shall be supplied with O.S. & Y. gate valves.

Approved Manufacturer/Models (or Part Numbers)

1. Ames 3000SS
2. Conbraco DCDA2LF 4A
3. Watts 774DCDA
4. Wilkins 350ASTDA

REDUCED PRESSURE ZONE DOUBLE CHECK VALVE BACKFLOW PREVENTER

Reduced Pressure Zone Double Check Valve Backflow Preventers ANSI/AWWA C511, and ASSE 1013, latest revisions. All assemblies shall be approved by both ASSE and the University of Southern California Foundation for Cross-CoMection Control of Hydraulic Research, and shall be supplied only in approved Configurations, including shut-off valves.

Reduced Pressure Zone Double Check Valve Backflow Preventors shall consist of two line-sized independently acting check valves, internally force loaded to a normal closed position, and separated by an intermediate chamber (or zone) in which there is a hydraulically operated relief means for venting atmosphere, which is internally force loaded to a normally open position.

Unless specified otherwise at the time of order, all assemblies shall be supplied with non-rising stem gate valves.

1-1/2" & 2" assemblies shall be constructed of Lead-Free Brass.

2-1/2" – 12" assemblies shall have stainless steel bodies.

Approved Manufacturers/Models (or Part Numbers)

1-1/2" & 2"	2-1/2" – 12"
1. Ames 4000B	1. Ames 4000SS
2. Conbraco RPLF4A	2. Conbraco RPLF4A
3. Watts LF009	3. Watts 994
4. Wilkins 375XL	4. Wilkins 375AST

DUAL CHECK VALVE BACKFLOW PREVENTER

Dual Check Valve Backflow Preventers shall conform to ANSI/AWWA C506, and ANSI/ASSE 1024, latest revisions.

Dual Check Valve Backflow Preventers shall consist of two independently acting poppet type check valves, internally force loaded to a normal closed position, designed and constructed to operate under intermittent or continuous pressure conditions. Unless otherwise specified, Dual Check Valves shall be of the straight-body design and shall be designed such that check assemblies may be field replaced without removal of valve body from line. Rated working pressure for Dual Check Valves shall be a minimum of 175 psi.

Unless specified otherwise at the time of order, Dual Check Valves shall show female iron pipe threads on inlet connections as well as outlet (FIP x FIP).

Approved Manufacturers/Models (or Part Numbers)

3/4" – 1"	1-1/2" – 2"
1. A.Y. McDonald 711	1. Ames LF2000B
2. Conbraco DUCLF4N	2. Conbraco DCLF4A
3. Watts LF7	3. Watts LF007
4. Wilkins 700XL	4. Wilkins 350XL

IMPORTANT INFORMATION: No-Lead Brass Fittings

a. All fittings and valves shall be manufactured in accordance with AWWA Standard C-800, latest revision, and as further specified in these technical specifications.

a.i Exception: Any brass part of the fitting or valve in contact with potable water shall be made of a "No-Lead Brass", defined for this specification as UNS Copper Alloy No. C89520 or C89833 in accordance with the chemical and mechanical requirements of ASTM B584 and AWWA C-800. This "No-Lead Brass" alloy shall not contain more than nine one hundredths of one percent (0.25% or less) total lead content by weight.

a.ii Any Brass part of the fitting or valve not in contact with potable water shall be made of 85-5- 5-5 brass as defined for this specification as UNS Copper Alloy C83600 per ASTM B62, ASTM B584 and AWWA C-800.

METER VAULTS

Panel vaults must be constructed of reinforced polymer concrete manufactured in molded structural shapes. The inner surface should consist of a heavy gel coat of polyester resin to provide a smooth non-abrasive working surface. The surface is to be backed by a double layer of heavy weave fiberglass type material.

Each enclosure shall include a one-piece collar to keep the enclosure square during backfill operation or after the ground settles.

The lid shall be a non-locking type with a logo "WATER" imprinted.

Cover shall have a service load of approximately 8,000# over a 10 inch square.

Meter vaults shall be CDR MODEL WA00(SIZE) - one piece only or approved equal.

Meter Vaults 3' x 5' x 3' and larger shall be delivered on individual pallets.

NO DOUBLE STACKED VAULTS WILL BE ACCEPTED.

METER BOXES**STANDARD METER BOXES**

- PLASTIC METER BOX (10" X 15" X 10") BOX ONLY
- STANDARD METER BOX LID (SOLID) LC-528
- STANDARD METER BOX LID (WITH 2" HOLE) LC-528T

JUMBO METER BOXES

- JUMBO METER BOXES (13" X 20" X 12") BOX ONLY
- JUMBO METER BOX LID (SOLID) LC-2115
- JUMBO METER BOX LID (WITH 2" HOLE) LC-2115T

APPROVED MANUFACTURERS

CARSON – MODEL 1220-12

APPROVED EQUAL

SOLID CAST IRON LIDS:

RUSSELL – MODEL LC2115 OR APPROVED EQUAL

METER BOXES FOR USE IN CONCRETE

- 11" X 18" X 12" METER BOX & D I LID WITH MAXIMUM READER(MSP)
- 13" X 24" X 12" METER BOX & D I LID WITH MAXIMUM READER(MSP)

APPROVED MANUFACTURER

MID-STATES PLASTICS – MODEL BCF SERIES

APPROVED EQUAL

Schedule 8

METER, WATER - ELECTROMAGNETIC

5/8" - 1" ELECTROMAGNETIC WATER METERS

Meters shall be electromagnetic flow measurement technology with an operating range as shown below in Specifications.

Must conform to the following standards as most recently revised: American Water Works Standard C-700 and C-710 for accuracy and pressure loss requirements; NSF Standard 61 Annex G.

Construction

External housing shall be thermal plastic. The encased measuring device shall be comprised of a polyphenylene sulfide alloy flow tube with externally-threaded spud ends. Embedded in the flow tube shall be magnetic flow sensors and a replaceable strainer screen. The register shall be all electronic, programmable, and hermetically sealed with a tempered glass cover. The meter system shall have a twenty (20) year life cycle, along with a twenty (20) year battery life guarantee. Meter must prevent removal of the register and have a means to indicate any attempt to tamper with the meter.

Electronic register

- Must read in cubic feet
- Must have AMR output from a single register
- Must be supplied with three AMR connections (red, green, black wires)
- Connection between register and meter transceiver unit shall be accomplished with use of all three terminals & Touch Coupler connection (or approved equivalent)
- AMR output data format shall be 7-bit ASCII (American Standard Code of Information Interchange) digital, plus an even parity bit
- Upon AMR interrogation the meter shall transmit a reading (# of digits customer specified) and an eight (8) digit register identification number which is to be factory programmed as to protect the system integrity and eliminate possible field programming duplication
- AMR resolution units fully programmable
- Highest AMR Resolution Required: 5/8" – 1" = .1 (Hundredths) Cubic Feet & 4" – 8" = 1 (Single) Cubic Foot
- Integral data logging capability
 - 1056 data points minimum
 - Interval available: 15 minutes, hourly, or daily
 - Logged information to include date, time, hourly max flow, hourly consumption, max flow, average flow, average consumption, and total consumption
- Large, easy-to-read LCD display that includes battery life and empty pipe indicators
- 20-year battery life and accuracy guarantee

Performance

Meters shall operate up to a working pressure of 200 pounds per square inch, without leakage or damage to any parts. Accuracy shall not be affected by variations in pressure up to 200 psi. The meter shall be accurate and perform for twenty (20) years from date of shipment.

AMR/AMI Systems

Meter must be compatible with current Sensus (or approved equivalent) AMR/AMI systems.

Specifications

Service	Measurement of cold water with flow in one direction only
Normal Operating Flow Range (100% +/- 1.5% of actual throughput)	5/8" (DN 15mm) size: 0.11 to 25 gpm (0.02 m ³ h to 5.7 m ³ h) 3/4" (DN 20 mm) size: 0.11 to 35 gpm (0.02 m ³ h to 8.0 m ³ h) 1" (DN 25mm) size: 0.4 to 55 gpm (0.09 m ³ h to 12.5 m ³ h)
Low Flow Registration (95%-101.5%)	5/8" (DN 15mm) size: 0.03 gpm (0.007 m ³ h) 3/4" (DN 20 mm) size: 0.03 gpm (0.007 m ³ h) 1" (DN 25mm) size: 0.11 gpm (0.025 m ³ h)
Maximum Pressure Loss	5/8" (DN 15mm) size: 4 psi at 15 gpm (0.3 bar at 3.4 m ³ h) 3/4" (DN 20 mm) size: 2 psi at 15 gpm (0.1 bar at 3.4 m ³ h) 1" (DN 25mm) size: 2 psi at 25 gpm (0.1 bar at 5.7 m ³ h)
Maximum Operating Pressure	200 psi (13.8 bar)

Guarantee

All meters will be guaranteed to perform accuracy levels above for a period of 20 years from the date of shipment.

Intent

Subject meter specifications are designed to establish minimum guidelines for selecting an extremely critical metering device. Areas of concern to be evaluated in the selection process include, but are not limited to, ease of installation, operational features and benefits, readability, and future system maintenance expense. A design which reflects longevity of proper operation in all elements and high degree of sustained accuracy within the entire range of the meter assembly is to be considered mandatory. Enhanced accuracy levels and performance are desired and will not be compromised.

METER, WATER – TURBINE

1 1/2" - 10" TURBINE WATER METERS

The meter package shall meet or exceed all requirements of ANSI/AWWA Standard C701 for Class II turbine meter assemblies as well as ANSI/AWWA C700 Residential Standard. Each meter assembly shall be performance tested to ensure compliance.

Maincases

The meter main case shall be of epoxy coated ductile iron composition. The epoxy coating shall be provided as standard fusion-bonded and adhere to NSF for No-lead regulation compliance.

A built-in test port is mandatory. Must be available in these various laying length options:

1 1/2" – 13", 2" – 15 1/4" & 17", 3" – 17" & 19", 4" – 20" & 23", 6" – 24" & 27", 8" – 31 1/8", 10" – 41 1/8"

Performance

The meter assembly shall have performance capability of continuous operation up to the rated maximum flows as listed below without affecting long-term accuracy or causing any undue component wear. The meter assembly shall also provide a 25% flow capacity in excess of the maximum flows listed for intermittent flow demands. Maximum headloss through the meter / strainer assembly shall not exceed those listed in the Operating Characteristics table per meter size.

Measuring Chamber

The measuring chamber shall consist of a measuring element, removable housing, and an all-electronic register. The measuring element shall be mounted on a horizontal, stationary stainless steel shaft with sleeve bearings and be essentially weightless in water (only one moving part). The measuring element comes integrated with the advanced Floating Ball Technology design. The measuring chamber shall be capable of operating within the above listed accuracy limits without calibration when transferred from one main case to another of the same size. The measuring shall be so configured to capture all flows as specified below, without the requirement of an automatic valve. Meters with manual calibration adjusters will not be accepted.

Operating Characteristics

Meter Size	Low Flow (95% Min)	Operating Range (98.5-101.5%)	Intermittent Flows (98.5-101.5%)	Pressure Loss (Not to Exceed)
1 ½"	0.75 gpm	1.25 to 160 gpm	200 gpm	6.9 psi @ 160 gpm
2"	1.0 gpm	1.5 to 200 gpm	250 gpm	7.0 psi @ 200 gpm
3"	1.5 gpm	2.5 to 500 gpm	650 gpm	5.1 psi @ 500 gpm
4"	2.0 gpm	3.0 to 1000 gpm	1250 gpm	8.7 psi @ 1000 gpm
6"	2.5 gpm	4.0 to 2000 gpm	2500 gpm	8.2 psi @ 2000 gpm
8"	4.0 gpm	5.0 to 3500 gpm	4700 gpm	5.1 psi @ 3500 gpm
10"	5.0 gpm	6.0 to 5500 gpm	7000 gpm	7.2 psi @ 5500 gpm

Direct Magnetic Drive System

The direct magnetic drive shall occur between the motion of the measuring element blade position and the electronic register. The direct drive system with Floating Ball Technology is designed to extend service life, enhance low flow sensitivity and provide extended flow capacity and overall accuracy of the meter assembly. Any and all additional intermediate, magnetic or mechanical, drive couplings or gearing are not acceptable.

Electronic Register

- Must read in cubic feet
- Must have AMR & pulse outputs from a single register
- Must be supplied with three AMR connections (red, green, black wires)
- Connection between register and meter transceiver unit shall be accomplished with use of all three terminals & Touch Coupler connection (or approved equivalent)
- AMR output data format shall be 7-bit ASCII (American Standard Code of Information Interchange) digital, plus an even parity bit
- Upon AMR interrogation the meter shall transmit a reading (# of digits customer specified) and an eight (8) digit register identification number which is to be factory programmed as to protect the system integrity and eliminate possible field programming duplication
- AMR resolution units fully programmable
- Highest AMR Resolution Required: 1.5" – 3" = .1 (Tenths) Cubic Feet & 4" – 10" = 1 (Single) Cubic Feet
- Pulse output frequency fully programmable
- Highest Pulse Resolution Required: 1.5" – 3" = .1 (Tenths) Cubic Feet & 4" – 10" = 1 (Single) Cubic Feet
- Integral data logging capability
- Integral resettable meter accuracy testing feature
- Large, easy-to-read LCD display
- 10-year battery life guarantee

Maximum Operating Pressure

The meter assembly shall operate properly without leakage, damage, or malfunction up to a maximum working pressure of 200 pounds per square inch (psig).

Strainers

The meter strainer shall be integral and cast as part of the meter's main case. The strainer's screen shall have a minimum net open area of at least two (2) times the pipe opening and be a V-shaped configuration for the purpose of maintaining a full unobstructed flow pattern. The strainer body shall be a coated ductile iron fusion-bonded epoxy identical to that of the meter's main case. All fasteners shall be stainless steel capable of maintaining the following static pressure ratings and physical dimensions:

Meter Size	Maximum Operating Pressure	Centerline to Strainer Base	Overall Length (Not to Exceed)
1 ½"	200 psig	2 5/16"	13"
2"	200 psig	2 5/16"	17"
3"	200 psig	4 1/8"	19"
4"	200 psig	4 ¾"	23"
6"	200 psig	5 ¾"	27"
8"	200 psig	6 ¾"	30 1/8"
10"	200 psig	8 1/2"	41 1/8"

Straightening Vanes

A straightening vane assembly is mandatory and shall be positioned directly upstream of the measuring element. The straightening vane assembly shall be an integral component of the measuring chamber.

Connections

Flanges for the 1-1/2" and 2" size meter assemblies shall be of the 2-bolt oval flange configuration. The 3", 4", 6", 8" & 10" size meter assemblies shall have flanges of the Class 125 round type, flat faced and shall conform to ANSI B16.1 for specified diameter, drilling and thickness.

Certifications and Markings

All sizes of meter packages shall display the sizes, model, manufacturer name, and direction of flow. Such display shall be cast on the side of the meter main case.

Guarantee

All meters will be guaranteed against defects in materials and workmanship for a period of one (1) year from the date of shipment.

Intent

Subject meter specifications are designed to establish minimum guidelines for selecting an extremely critical metering device. Areas of concern to be evaluated in the selection process include, but are not limited to, ease of installation, operational features and benefits, readability, and future system maintenance expense. A design which reflects longevity of proper operation in all elements and high degree of sustained accuracy within the entire range of the meter assembly is to be considered mandatory. Enhanced accuracy levels and performance are desired and will not be compromised.

AMR/AMI Systems

Meter must be compatible with current Sensus (or approved equivalent) AMR/AMI systems.

METER, WATER – COMPOUND

1 1/2" - 10" COMPOUND WATER METERS

The meter package shall meet or exceed all requirements of ANSI/AWWA Standard C701 and C702 for Class II compound and turbine meter assemblies. Each meter assembly shall be performance tested to ensure compliance.

Main cases

The meter main case shall be of epoxy coated ductile iron composition. The epoxy coating shall be provided as standard fusion-bonded and adhere to NSF for No-lead regulation compliance.

A built-in test port is mandatory. Must be available in these various laying length options: 1-½" – 13", 2" – 15 ¼" & 17", 3" – 17" & 19", 4" – 20" & 23", 6" – 24" & 27", 8" – 31-1/8", 10" – 41-1/8"

Performance

The meter assembly shall have performance capability of continuous operation up to the rated maximum flows as listed below without affecting long-term accuracy or causing any undue component wear. The meter assembly shall also provide a 25% flow capacity in excess of the maximum flows listed for intermittent flow demands. Maximum head loss through the meter / strainer assembly shall not exceed those listed in the following table per meter size.

Measuring Chamber

The measuring chamber shall consist of a measuring element, removable housing, and an all-electronic register. The measuring element shall be mounted on a horizontal, stationary stainless steel shaft with sleeve bearings and be essentially weightless in water (only one moving part). The measuring element comes integrated with the advanced Floating Ball Technology design. The measuring chamber shall be capable of operating within the above listed accuracy limits without calibration when transferred from one main case to another of the same size. The measuring shall be so configured to capture all flows as specified above, without the requirement of an automatic valve. Meters with manual calibration adjusters will not be accepted.

Operating Characteristics

Meter Size	Low Flow (95% Min)	Operating Range (98.5-101.5%)	Intermittent Flows (98.5-101.5%)	Pressure Loss (Not to Exceed)
1 ½"	0.25 gpm	0.5 to 160 gpm	200 gpm	6.9 psi @ 160 gpm
2"	0.25 gpm	0.5 to 160 gpm	200 gpm	4.3 psi @ 160 gpm
3"	0.5 gpm	1.0 to 400 gpm	500 gpm	3.2 psi @ 400 gpm
4"	0.75 gpm	1.5 to 800 gpm	1000 gpm	6.4 psi @ 800 gpm
6"	1.5 gpm	3.0 to 1600 gpm	2000 gpm	5.5 psi @ 1600 gpm
8"	2.5 gpm	4.0 to 2700 gpm	3400 gpm	4.0 psi @ 2700 gpm
10"	3.5 gpm	5.0 to 4000 gpm	5000 gpm	4.5 psi @ 4000 gpm

Direct Magnetic Drive System

The direct magnetic drive shall occur between the motion of the measuring element blade position and the electronic register. The direct drive system with Floating Ball Technology is designed to extend service life, enhance low flow sensitivity and provide extended flow capacity and overall accuracy of the meter assembly. Any and all additional intermediate, magnetic or mechanical, drive couplings or gearing are not acceptable.

Electronic Register

- Must Read in Cubic Feet
- Must have AMR & Pulse outputs from a single register
- Must be supplied with three AMR connections (Red, Green, Black wires)
- Connection between register and meter transceiver unit shall be accomplished with use of all three terminals & Touch Coupler connection (or approved equivalent)
- AMR output data format shall be 7-bit ASCII (American Standard Code of Information Interchange) digital, plus an even parity bit
- Upon AMR interrogation the meter shall transmit a reading (# of Digits Customer specified) and an eight (8) digit register identification number which is to be factory programmed as to protect the system integrity and eliminate possible field programming duplication
- AMR resolution units fully programmable
- Highest AMR Resolution Required: 1.5" – 3" = .1 (Tenths) Cubic Feet & 4" – 10" = 1 (Single) Cubic Feet
- Pulse output frequency fully programmable
- Highest Pulse Resolution Required: 1.5" – 3" = .1 (Tenths) Cubic Feet & 4" – 10" = 1 (Single) Cubic Feet
- Integral data logging capability
- Integral resettable meter accuracy testing feature
- Large, easy-to-read LCD display
- 10-year battery life guarantee

Maximum Operating Pressure

The meter assembly shall operate properly without leakage, damage, or malfunction up to a maximum working pressure of 200 pounds per square inch (psig).

Strainers

The meter strainer shall be integral and cast as part of the meter’s main case. The strainer’s screen shall have a minimum net open area of at least two (2) times the pipe opening and be a V-shaped configuration for the purpose of maintaining a full unobstructed flow pattern. The strainer body shall be a coated ductile iron fusion-bonded epoxy identical to that of the meter’s main case. All fasteners shall be stainless steel capable of maintaining the following static pressure ratings and physical dimensions:

Meter Size	Maximum Operating Pressure	Centerline to Strainer Base	Overall Length (Not to Exceed)
1 ½"	200 psig	2 5/16"	13"
2"	200 psig	2 5/16"	15 ¼"
3"	200 psig	4 1/8"	17"
4"	200 psig	4 ¾"	20"
6"	200 psig	5 ¾"	24"
8"	200 psig	6 ¾"	30 1/8"
10"	200 psig	8 ½"	41 1/8"

Straightening Vanes

A straightening vane assembly is mandatory and shall be positioned directly upstream of the measuring element. The straightening vane assembly shall be an integral component of the measuring chamber.

Connections

Flanges for the 1-1/2" and 2" size meter assemblies shall be of the 2-bolt oval flange configuration. The 3" and 4" size meter assemblies shall have flanges of the Class 125 round type, flat faced and shall conform to ANSI B16.1 for specified diameter, drilling and thickness.

Certifications and Markings

All sizes of meter packages shall display the sizes, model, manufacturer name, and direction of flow. Such display shall be cast on the side of the meter main case.

Guarantee

All meters will be guaranteed against defects in materials and workmanship for a period of one (1) year from the date of shipment.

Intent

Subject meter specifications are designed to establish minimum guidelines for selecting an extremely critical metering device. Areas of concern to be evaluated in the selection process include, but are not limited to, ease of installation, operational features and benefits, readability, and future system maintenance expense. A design which reflects longevity of proper operation in all elements and high degree of sustained accuracy within the entire range of the meter assembly is to be considered mandatory. Enhanced accuracy levels and performance are desired and will not be compromised.

AMR/AMI Systems

Meter must be compatible with current Sensus (or approved equivalent) AMR/AMI systems.

METER, WATER – ELECTROMAGNETIC WITH ITRON CABLE**5/8" - 1" ELECTROMAGNETIC WATER METERS WITH ITRON CABLE**

Meters shall be electromagnetic flow measurement technology with an operating range as shown below in Specifications.

Must conform to the following standards as most recently revised: American Water Works Standard C-700 and C-710 for accuracy and pressure loss requirements; NSF Standard 61 Annex G.

Construction

External housing shall be thermal plastic. The encased measuring device shall be comprised of a polyphenylene sulfide alloy flow tube with externally-threaded spud ends. Embedded in the flow tube shall be magnetic flow sensors and a replaceable strainer screen. The register shall be all electronic, programmable, and hermetically sealed with a tempered glass cover. The meter system shall have a twenty (20) year life cycle, along with a twenty (20) year battery life guarantee. Meter must prevent removal of the register and have a means to indicate any attempt to tamper with the meter.

Electronic register

- Must read in cubic feet
- Must have AMR output from a single register
- Must be supplied with three AMR connections (red, green, black wires). Cable must be compatible with ITRON.
- Connection between register and meter transceiver unit shall be accomplished with use of all three terminals & Touch Coupler connection (or approved equivalent)

- AMR output data format shall be 7-bit ASCII (American Standard Code of Information Interchange) digital, plus an even parity bit
- Upon AMR interrogation the meter shall transmit a reading (# of digits customer specified) and an eight (8) digit register identification number which is to be factory programmed as to protect the system integrity and eliminate possible field programming duplication
- AMR resolution units fully programmable
- Highest AMR Resolution Required: 5/8" – 1" = .1 (Hundredths) Cubic Feet & 4" – 8" = 1 (Single) Cubic Foot
- Integral data logging capability
 - 1056 data points minimum
 - Interval available: 15 minutes, hourly, or daily
 - Logged information to include date, time, hourly max flow, hourly consumption, max flow, average flow, average consumption, and total consumption
- Large, easy-to-read LCD display that includes battery life and empty pipe indicators
- 20-year battery life and accuracy guarantee

Performance

Meters shall operate up to a working pressure of 200 pounds per square inch, without leakage or damage to any parts. Accuracy shall not be affected by variations in pressure up to 200 psi. The meter shall be accurate and perform for twenty (20) years from date of shipment.

AMR/AMI Systems

Meter must be compatible with ITRON (or approved equivalent) AMR/AMI systems.

Specifications

Service	Measurement of cold water with flow in one direction only
Normal Operating Flow Range (100% +/- 1.5% of actual throughput)	5/8" (DN 15mm) size: 0.11 to 25 gpm (0.02 m ³ h to 5.7 m ³ h) 3/4" (DN 20 mm) size: 0.11 to 35 gpm (0.02 m ³ h to 8.0 m ³ h) 1" (DN 25mm) size: 0.4 to 55 gpm (0.09 m ³ h to 12.5 m ³ h)
Low Flow Registration (95%-101.5%)	5/8" (DN 15mm) size: 0.03 gpm (0.007 m ³ h) 3/4" (DN 20 mm) size: 0.03 gpm (0.007 m ³ h) 1" (DN 25mm) size: 0.11 gpm (0.025 m ³ h)
Maximum Pressure Loss	5/8" (DN 15mm) size: 4 psi at 15 gpm (0.3 bar at 3.4 m ³ h) 3/4" (DN 20 mm) size: 2 psi at 15 gpm (0.1 bar at 3.4 m ³ h) 1" (DN 25mm) size: 2 psi at 25 gpm (0.1 bar at 5.7 m ³ h)
Maximum Operating Pressure	200 psi (13.8 bar)

Guarantee

All meters will be guaranteed to perform accuracy levels above for a period of 20 years from the date of shipment.

Intent

Subject meter specifications are designed to establish minimum guidelines for selecting an extremely critical metering device. Areas of concern to be evaluated in the selection process include, but are not limited to, ease of installation, operational features and benefits, readability, and future system maintenance expense. A design which

reflects longevity of proper operation in all elements and high degree of sustained accuracy within the entire range of the meter assembly is to be considered mandatory. Enhanced accuracy levels and performance are desired and will not be compromised.

METER, WATER – TURBINE WITH ITRON CABLE

1 1/2" - 10" TURBINE WATER METERS WITH ITRON CABLE

The meter package shall meet or exceed all requirements of ANSI/AWWA Standard C701 for Class II turbine meter assemblies as well as ANSI/AWWA C700 Residential Standard. Each meter assembly shall be performance tested to ensure compliance.

Main cases

The meter main case shall be of epoxy coated ductile iron composition. The epoxy coating shall be provided as standard fusion-bonded and adhere to NSF for No-lead regulation compliance.

A built-in test port is mandatory. Must be available in these various laying length options:

1 ½" – 13", 2" – 15 ¼" & 17", 3" – 17" & 19", 4" – 20" & 23", 6" – 24" & 27", 8" – 31 1/8", 10" – 41 1/8"

Performance

The meter assembly shall have performance capability of continuous operation up to the rated maximum flows as listed below without affecting long-term accuracy or causing any undue component wear. The meter assembly shall also provide a 25% flow capacity in excess of the maximum flows listed for intermittent flow demands. Maximum head loss through the meter / strainer assembly shall not exceed those listed in the Operating Characteristics table per meter size.

Measuring Chamber

The measuring chamber shall consist of a measuring element, removable housing, and an all-electronic register. The measuring element shall be mounted on a horizontal, stationary stainless steel shaft with sleeve bearings and be essentially weightless in water (only one moving part). The measuring element comes integrated with the advanced Floating Ball Technology design. The measuring chamber shall be capable of operating within the above listed accuracy limits without calibration when transferred from one main case to another of the same size. The measuring shall be so configured to capture all flows as specified below, without the requirement of an automatic valve. Meters with manual calibration adjusters will not be accepted.

Operating Characteristics

Meter Size	Low Flow (95% Min)	Operating Range (98.5-101.5%)	Intermittent Flows (98.5-101.5%)	Pressure Loss (Not to Exceed)
1 ½"	0.75 gpm	1.25 to 160 gpm	200 gpm	6.9 psi @ 160 gpm
2"	1.0 gpm	1.5 to 200 gpm	250 gpm	7.0 psi @ 200 gpm
3"	1.5 gpm	2.5 to 500 gpm	650 gpm	5.1 psi @ 500 gpm
4"	2.0 gpm	3.0 to 1000 gpm	1250 gpm	8.7 psi @ 1000 gpm
6"	2.5 gpm	4.0 to 2000 gpm	2500 gpm	8.2 psi @ 2000 gpm
8"	4.0 gpm	5.0 to 3500 gpm	4700 gpm	5.1 psi @ 3500 gpm
10"	5.0 gpm	6.0 to 5500 gpm	7000 gpm	7.2 psi @ 5500 gpm

Direct Magnetic Drive System

The direct magnetic drive shall occur between the motion of the measuring element blade position and the electronic register. The direct drive system with Floating Ball Technology is designed to extend service life, enhance

low flow sensitivity and provide extended flow capacity and overall accuracy of the meter assembly. Any and all additional intermediate, magnetic or mechanical, drive couplings or gearing are not acceptable.

Electronic Register

- Must read in cubic feet
- Must have AMR & pulse outputs from a single register
- Must be supplied with three AMR connections (red, green, black wires) Cable must be compatible with ITRON.
- Connection between register and meter transceiver unit shall be accomplished with use of all three terminals & Touch Coupler connection (or approved equivalent)
- AMR output data format shall be 7-bit ASCII (American Standard Code of Information Interchange) digital, plus an even parity bit
- Upon AMR interrogation the meter shall transmit a reading (# of digits customer specified) and an eight (8) digit register identification number which is to be factory programmed as to protect the system integrity and eliminate possible field programming duplication
- AMR resolution units fully programmable
- Highest AMR Resolution Required: 1.5" – 3" = .1 (Tenths) Cubic Feet & 4" – 10" = 1 (Single) Cubic Feet
- Pulse output frequency fully programmable
- Highest Pulse Resolution Required: 1.5" – 3" = .1 (Tenths) Cubic Feet & 4" – 10" = 1 (Single) Cubic Feet
- Integral data logging capability
- Integral resettable meter accuracy testing feature
- Large, easy-to-read LCD display
- 10-year battery life guarantee

Maximum Operating Pressure

The meter assembly shall operate properly without leakage, damage, or malfunction up to a maximum working pressure of 200 pounds per square inch (psig).

Strainers

The meter strainer shall be integral and cast as part of the meter’s main case. The strainer’s screen shall have a minimum net open area of at least two (2) times the pipe opening and be a V-shaped configuration for the purpose of maintaining a full unobstructed flow pattern. The strainer body shall be a coated ductile iron fusion-bonded epoxy identical to that of the meter’s main case. All fasteners shall be stainless steel capable of maintaining the following static pressure ratings and physical dimensions:

Meter Size	Maximum Operating Pressure	Centerline to Strainer Base	Overall Length (Not to Exceed)
1 ½"	200 psig	2 5/16"	13"
2"	200 psig	2 5/16"	17"
3"	200 psig	4 1/8"	19"
4"	200 psig	4 ¾"	23"
6"	200 psig	5 ¾"	27"
8"	200 psig	6 ¾"	30 1/8"
10"	200 psig	8 1/2"	41 1/8"

Straightening Vanes

A straightening vane assembly is mandatory and shall be positioned directly upstream of the measuring element. The straightening vane assembly shall be an integral component of the measuring chamber.

Connections

Flanges for the 1-1/2" and 2" size meter assemblies shall be of the 2-bolt oval flange configuration. The 3", 4", 6", 8" & 10" size meter assemblies shall have flanges of the Class 125 round type, flat faced and shall conform to ANSI B16.1 for specified diameter, drilling and thickness.

Certifications and Markings

All sizes of meter packages shall display the sizes, model, manufacturer name, and direction of flow. Such display shall be cast on the side of the meter main case.

Guarantee

All meters will be guaranteed against defects in materials and workmanship for a period of one (1) year from the date of shipment.

Intent

Subject meter specifications are designed to establish minimum guidelines for selecting an extremely critical metering device. Areas of concern to be evaluated in the selection process include, but are not limited to, ease of installation, operational features and benefits, readability, and future system maintenance expense. A design which reflects longevity of proper operation in all elements and high degree of sustained accuracy within the entire range of the meter assembly is to be considered mandatory. Enhanced accuracy levels and performance are desired and will not be compromised.

AMR/AMI Systems

Meter must be compatible with ITRON (or approved equivalent) AMR/AMI systems.

METER, WATER – COMPOUND WITH ITRON CABLE**1 1/2" - 10" COMPOUND WATER METERS WITH ITRON CABLE**

The meter package shall meet or exceed all requirements of ANSI/AWWA Standard C701 and C702 for Class II compound and turbine meter assemblies. Each meter assembly shall be performance tested to ensure compliance.

Main cases

The meter main case shall be of epoxy coated ductile iron composition. The epoxy coating shall be provided as standard fusion-bonded and adhere to NSF for No-lead regulation compliance.

A built-in test port is mandatory. Must be available in these various laying length options: 1-½" – 13", 2" – 15 ¼" & 17", 3" – 17" & 19", 4" – 20" & 23", 6" – 24" & 27", 8" – 31-1/8", 10" – 41-1/8"

Performance

The meter assembly shall have performance capability of continuous operation up to the rated maximum flows as listed below without affecting long-term accuracy or causing any undue component wear. The meter assembly shall also provide a 25% flow capacity in excess of the maximum flows listed for intermittent flow demands. Maximum head loss through the meter / strainer assembly shall not exceed those listed in the following table per meter size.

Measuring Chamber

The measuring chamber shall consist of a measuring element, removable housing, and an all-electronic register. The measuring element shall be mounted on a horizontal, stationary stainless steel shaft with sleeve bearings and be essentially weightless in water (only one moving part). The measuring element comes integrated with the advanced Floating Ball Technology design. The measuring chamber shall be capable of operating within the above listed accuracy limits without calibration when transferred from one main case to another of the same size. The

measuring shall be so configured to capture all flows as specified above, without the requirement of an automatic valve. Meters with manual calibration adjusters will not be accepted.

Operating Characteristics

Meter Size	Low Flow (95% Min)	Operating Range (98.5-101.5%)	Intermittent Flows (98.5-101.5%)	Pressure Loss (Not to Exceed)
1 ½"	0.25 gpm	0.5 to 160 gpm	200 gpm	6.9 psi @ 160 gpm
2"	0.25 gpm	0.5 to 160 gpm	200 gpm	4.3 psi @ 160 gpm
3"	0.5 gpm	1.0 to 400 gpm	500 gpm	3.2 psi @ 400 gpm
4"	0.75 gpm	1.5 to 800 gpm	1000 gpm	6.4 psi @ 800 gpm
6"	1.5 gpm	3.0 to 1600 gpm	2000 gpm	5.5 psi @ 1600 gpm
8"	2.5 gpm	4.0 to 2700 gpm	3400 gpm	4.0 psi @ 2700 gpm
10"	3.5 gpm	5.0 to 4000 gpm	5000 gpm	4.5 psi @ 4000 gpm

Direct Magnetic Drive System

The direct magnetic drive shall occur between the motion of the measuring element blade position and the electronic register. The direct drive system with Floating Ball Technology is designed to extend service life, enhance low flow sensitivity and provide extended flow capacity and overall accuracy of the meter assembly. Any and all additional intermediate, magnetic or mechanical, drive couplings or gearing are not acceptable.

Electronic Register

- Must Read in Cubic Feet
- Must have AMR & Pulse outputs from a single register
- Must be supplied with three AMR connections (Red, Green, Black wires) Cable must be compatible with ITRON.
- Connection between register and meter transceiver unit shall be accomplished with use of all three terminals & Touch Coupler connection (or approved equivalent)
- AMR output data format shall be 7-bit ASCII (American Standard Code of Information Interchange) digital, plus an even parity bit
- Upon AMR interrogation the meter shall transmit a reading (# of Digits Customer specified) and an eight (8) digit register identification number which is to be factory programmed as to protect the system integrity and eliminate possible field programming duplication
- AMR resolution units fully programmable
- Highest AMR Resolution Required: 1.5" – 3" = .1 (Tenths) Cubic Feet & 4" – 10" = 1 (Single) Cubic Feet
- Pulse output frequency fully programmable
- Highest Pulse Resolution Required: 1.5" – 3" = .1 (Tenths) Cubic Feet & 4" – 10" = 1 (Single) Cubic Feet
- Integral data logging capability
- Integral resettable meter accuracy testing feature
- Large, easy-to-read LCD display
- 10-year battery life guarantee

Maximum Operating Pressure

The meter assembly shall operate properly without leakage, damage, or malfunction up to a maximum working pressure of 200 pounds per square inch (psig).

Strainers

The meter strainer shall be integral and cast as part of the meter’s main case. The strainer’s screen shall have a minimum net open area of at least two (2) times the pipe opening and be a V-shaped configuration for the purpose of maintaining a full unobstructed flow pattern. The strainer body shall be a coated ductile iron fusion-bonded epoxy identical to that of the meter’s main case. All fasteners shall be stainless steel capable of maintaining the following static pressure ratings and physical dimensions:

Meter Size	Maximum Operating Pressure	Centerline to Strainer Base	Overall Length (Not to Exceed)
1 ½"	200 psig	2 5/16"	13"
2"	200 psig	2 5/16"	15 ¼"
3"	200 psig	4 1/8"	17"
4"	200 psig	4 ¾"	20"
6"	200 psig	5 ¾"	24"
8"	200 psig	6 ¾"	30 1/8"
10"	200 psig	8 ½"	41 1/8"

Straightening Vanes

A straightening vane assembly is mandatory and shall be positioned directly upstream of the measuring element. The straightening vane assembly shall be an integral component of the measuring chamber.

Connections

Flanges for the 1-1/2" and 2" size meter assemblies shall be of the 2-bolt oval flange configuration. The 3" and 4" size meter assemblies shall have flanges of the Class 125 round type, flat faced and shall conform to ANSI B16.1 for specified diameter, drilling and thickness.

Certifications and Markings

All sizes of meter packages shall display the sizes, model, manufacturer name, and direction of flow. Such display shall be cast on the side of the meter main case.

Guarantee

All meters will be guaranteed against defects in materials and workmanship for a period of one (1) year from the date of shipment.

Intent

Subject meter specifications are designed to establish minimum guidelines for selecting an extremely critical metering device. Areas of concern to be evaluated in the selection process include, but are not limited to, ease of installation, operational features and benefits, readability, and future system maintenance expense. A design which reflects longevity of proper operation in all elements and high degree of sustained accuracy within the entire range of the meter assembly is to be considered mandatory. Enhanced accuracy levels and performance are desired and will not be compromised.

AMR/AMI Systems

Meter must be compatible with ITRON (or approved equivalent) AMR/AMI systems.

HYDRANT METER

Sensus Omni H2 hydrant meter, with built in strainer and techno check valve, hydrant support rod, 6' TR/PL cable, Cubic feet measuring, NST fire hose adapters

Meter Part # H3X2HX1FXAXX1ND

Schedule 9

MALE IRON PIPE X COMPRESSION ADAPTERS

All adapters shall fully comply with the AWWA C800 specifications.

All adapters shall have FULL 3/4" or 1" opening.

Adapters shall have compression nut with gripper ring and gasket providing a water tight seal by compressing of gasket around tubing and compressing the gripper ring providing high pull out resistance.

Compression nuts requiring a split type clamp with screw or bolt will not be accepted.

Schedule 10

FITTINGS, DUCTILE IRON, MECHANICAL JOINT

All fittings need to be Ductile Iron.

All fittings are to have mechanical joint ends.

Must meet all applicable terms and provisions of standards ANSI/AWWA C153/A21.53-84 and ANSI/AWWA C111 ANSI A21.11 (current revisions). Specifications and Federal Specifications WW-p-421B.

Plain ends of all mechanical joint fittings to be beveled.

All mechanical joint fittings 4 through 36 inch must be at least 250 psig working pressure.

Mechanical joint fittings are to have a bituminous seal coat, NSF 61.

NOTE: Fittings are to be compact or standard (NO LONG RADIUS) and consist of tees, bends, wye branches, crosses, reducers and increasers, etc., without accessories.

Bids must be on a price per fitting less accessories basis to be acceptable.

Bids for mechanical joint caps and plugs must include center tapped with a 2 inch iron pipe thread tap.

FITTINGS TO BE ORDERED AS NEEDED.

APPROVED MANUFACTURERS

American Cast Iron Pipe

Clow

U. S. Pipe

Tyler Union Foundry

Approved equal

FITTINGS, DUCTILE IRON, FLANGED JOINT

All fittings need to be Ductile Iron.

All fittings are to have flanged ends.

BID NO. 9070-083021-1

Signature _____

Must meet all applicable requirements to ANSI/AWWA C110/A21.10 (current revisions) Specifications and Federal Specifications WW-p-421B.

All flanged fittings 4 through 36 inch must be at least 250 psig working pressure.

Flanges are to be ANSI Class 125 B16.1.

Flanged fittings are to come without accessories.

Flanged fittings are to have a bituminous seal coat, NSF 61.

NOTE: Fittings consist of tees, bends, wye branches, crosses, reducers and increasers, etc.

Bids for flanged joint caps and plugs must include center tapped with a 2 inch iron pipe thread tap.

Fittings to be compact or standard (NO LONG RADIUS); ANSI, AWWA, C153/A21.53-84.

FITTINGS ARE TO BE ORDERED AS NEEDED.

APPROVED MANUFACTURERS

American Cast Iron Pipe

Clow

U. S. Pipe

Tyler Union Foundry

Approved equal

GLANDS, MEGALUG

Mechanical joint restraint shall be incorporated in the design of the follower gland and shall include a restraining mechanism which, when actuated, imparts multiple wedging action against the pipe, increasing its resistance as the pressure increases.

Flexibility of the joint shall be maintained after burial. Glands shall be manufactured of ductile iron conforming to ASTM A 536-80. Restraining devices shall be of ductile iron heat treated to a minimum hardness of 370 BHN. Dimensions of the gland shall be such that it can be used with the standardized mechanical joint bell and tee-head bolts conforming to ANSI/AWWA A21.11 and ANSI/AWWA/A21.53 of latest revision. Twist-off nuts shall be used to insure proper actuating of the restraining devices. The mechanical joint restraint device shall have a working pressure of at least 250 psig with a minimum safety factor of 2:1 and shall be EBAA Iron, Inc., MEGALUG, UNIFLANGE or approved equal.

APPROVED MANUFACTURERS

EBAA Iron, Inc.

Tyler Union Foundry

Sigma

Ford Meter Box

COUPLINGS FOR 4" - 36" PIPE

Couplings should meet the specifications set forth in AWWA Standard C219.

Followers shall meet Ductile Iron ASTM A536 or Steel ASTM A36. Middle ring shall meet Ductile Iron ASTM A536 or Steel ASTM A36.

Middle ring lengths stated for Items 900 - 929 are ***minimum acceptable lengths***.

Gaskets Styrene Butadiene Rubber (SBR) for water in accordance with ASTM D2000

BID NO. 9070-083021-1

Signature _____

Bolts minimum 5/8 inch and shall meet AWWA C111, ANSI A21.11 or ASTM A242
Minimum corrosion resistant shop coat NSF 61 approved.

APPROVED MANUFACTURERS

Ford Meter Box
JCM Industries
Romac Industries

Schedule 11

IOMAR THREAD SEALANT (Green Stuff)

Slow-Drying Soft-Set General Purpose Thread Sealant
NSF Certified and CSA Certified

T&T Tools Mighty Probing Rod

48" Overall Length
With Current Insulator

Schedule 12

BRASS PACK JOINT COUPLINGS

All Pack Joint fittings will be brass and sized properly to fit Schedule 40 and Schedule 80 PVC Pipe.
The following sizes will be needed: 1/2", 3/4", 1", 1 1/4", 1 1/2", 2".
Ford C77-xx-NL or equal.

BRASS RANGER COUPLINGS

All Ranger fittings must be brass.
The following sizes will be needed: 3/4" and 1"
AY McDonald 74758-11

Schedule 13

Snap Repair Clamps

Shell- Type 304 Stainless Steel
Lugs- Ductile Iron per ASTM A536

Wrap Repair Clamps

Shell- Type 304 Stainless Steel
Lugs- Ductile Iron per ASTM A536

Schedule 14

PIPE, PVC PRESSURE

All PVC Pipe must be equivalent to or better than the following:

- SDR 21 - CLASS 200 PVC
- ASTM - D1784-69 PVC Resins
- ASTM - D72.2-67 for PVC Pipe

All pipe to be in 20' lengths.
 Gaskets are to be permanently attached to couplings.
 Sufficient lubricant must be supplied with pipe.
 Bids must be on a price per linear foot basis.
 PIPE TO BE ORDERED AS NEEDED.

Schedule 15

PIPE, P V C SEWER

All PVC Pipe sizes 4"-12" must be equivalent to or better than the following:

SDR 26 - Heavy wall sewer pipe
 ASTM D-3034 and F-679
 ASTM F477 and ASTM D3139.
 ASTM D-3034 and ASTM D-2729 Standards
 All pipe to be in 14' lengths.

Gaskets are to be permanently attached to couplings.
 Sufficient lubricant must be supplied with pipe.
 Bids must be on a price per linear foot basis.

PIPE TO BE ORDERED AS NEEDED.

FITTINGS, P V C SEWER

4" through 18" gasket SDR 26 HW sewer fittings shall be manufactured in accordance with ASTM D 3034 and F1336 standards.

Fitting gaskets shall comply with ASTM F 477 or ASTM F 913.

Fitting gaskets shall be locked firmly in position to prevent displacement.

4" through 8" fittings shall be injection molded from virgin PVC compound having a minimum cell classification of 12454-B in accordance with, and certified by the National Sanitation Foundation (NSF), to meet ASTM D 1784.

10" through 15" gasket SDR 26 sewer fittings may be injection molded or fabricated from pipe meeting the requirements of ASTM D 3034.

Gasket joints of all fitting sizes must comply with ASTM D 3212 Internal Pressure Test (exfiltration) and Vacuum Test (infiltration) at 5 degrees of gasket joint deflection. Gasket SDR 26 sewer fittings shall be certified by the National Sanitation Foundation (NSF) to meet ASTM D 3034.

FITTINGS ARE TO BE ORDERED AS NEEDED

STAINLESS STEEL SHIELDED/SHEAR RING REPAIR COUPLINGS

1.0 Flexible Transition Couplings These shall be manufactured from elastomeric materials that comply with the applicable requirements of ASTM C 1173 Standard Specification for Flexible Transition Couplings.

2.0 The **purpose** of Flexible Transition Couplings is to form a leak proof joint between sections plain end pipe or fittings of the same or different materials such as cast iron, clay, ductile iron, concrete and plastic pipe in sizes ranging from 1 ¼" up to 30" with larger sizes available upon request.

3.0 Stainless Steel Hose Clamps Hose clamps should be constructed of series 300 premium grade stainless steel, including the housing and screw to insure a positive seal ranging in size from 1 1/16" through 21". The stainless steel hose clamps shall be tested to withstand the required minimum torque of 60 in-lbs and maximum free running torque of 4 in-lbs as to the applicable requirements in ASTM C 1173.

4.0 Stainless Steel Bolt Clamps Bolt clamps should be constructed of 316 stainless steel, to include the band, nut and screw. The stainless steel bolt clamps range in sizes from 4" through 15" and meet the required minimum torque of 60 in-lbs and maximum free running torque of 4 in-lbs as to the applicable requirements in ASTM C 1173.

5.0 Stainless Steel Shear Ring Shear rings should be manufactured from all series 300 premium grade stainless steel construction to ensure extra rigidity and strength, and provide protection in even the most unstable ground conditions. The shear rings need to be available for several types of piping, in the most popular sizes. They should be available in thicknesses of 0.007" and 0.012". Shear ring couplings need to be manufactured to conform to the functional requirements of ASTM C 1173.

6.0 Sealing Resistance Flexible Transition Couplings shall show no visible leakage while under an internal hydrostatic pressure of 4.3 psi as to the applicable requirements of ASTM C 1173.

7.0 Durometer Hardness Testing Flexible Transition Couplings shall have a shore "A" durometer (hardness) of 50-75 as to the applicable requirements of ASTM C 1173 and ASTM Test Method D 2240.

8.0 Marking Flexible Transition Couplings shall be marked with the manufacturers name or trademark, or both. The type and size of pipe for which the coupling is intended of the manufacturer's product number shall be marked on or attached to each coupling as to the applicable requirements of ASTM C 1173.

APPROVED MANUFACTURERS

Fernco

Mission Rubber

Indiana Seal

Schedule 16

TAPPING SLEEVES, STAINLESS STEEL

Tapping sleeve shall be fabricated from 304 Stainless Steel or its equivalent, CF8 Cast Stainless Steel. They shall have a pass through bolt design and provide 360 deg. seal around the pipe. Sleeve shall be fully passivized to return the stainless steel to its highest corrosion resistance. Flange outlets shall be indexed per MSS-SP60 to accept tapping valve. The lugs shall have a pass-through bolt design, to avoid alignment problems and allow tightening from either side of the pipe. Bolts shall not be integrally welded to the sleeve. Bolting lug shall be triangular design with a maximum of 3" bolt center spacing. Bolting hardware shall be a minimum of 304 Stainless Steel.

Body: Stainless Steel, 18-8 Type 304

Flange: CF8 Cast Stainless Steel - equivalent to 18-8 Type 304 Stainless Steel. ANSI 150lb. Drilling, recessed for tapping valve per MSS-SP 60.

BID NO. 9070-083021-1

Signature _____

Bolts: Stainless Steel, 18-8 Type 304**Branch Outlet:** Schedule 10 Stainless Steel Pipe**Gasket:** Full circumferential Virgin Styrene-Butadiene Rubber (SBR) - Compounded for use with water, salt solutions, mild acids and bases. Per ASTM D-2000 M4AA 607. Standard temperature range from -40 deg. to 150 deg. F (-40 deg. to 65 deg. C) constant, maximum intermittent 180 deg. F (82 deg. C).**Sleeve pressure rating with standard CF8 cast stainless steel flange:** Sleeves 4" – 24" nominal pipe sizes: 175 PSI working pressure, hydrostatic test pressure of 218 PSI (pressures per ANSI/AWWA C207 Standard).APPROVED MANUFACTURERS

JCM

Ford Meter Box

Romac

TAPPING SLEEVES, MECHANICAL JOINT DUCTILE IRON

Tapping sleeves shall be ductile iron construction meeting ASTM A536. Sleeve shall be coated with asphaltic varnish in compliance with NSF-61. Tapping sleeves shall be of the mechanical joint type. The mechanical joint ends shall be sealed by neoprene gaskets, compressed tightly around mains by means of a second flange or gland bolted to the end flange of the sleeve. Gasket and its seat inside the end flange of the sleeve shall be tapered or wedge shaped. The gasket shall be totally confined to prevent cold-flow when gland is tightened.

Tapping sleeves shall be suitable for use on pipe with AWWA specifications as follows: C102-53, C105-53, and C108-53.

Tapping sleeves shall have a working pressure of 200 psig.

The side outlet or branch connection outlet shall be machined and with a machined recess to match the machined projection of the tapping valve flange to assure correct alignment regardless of valve brand.

The longitudinal or side gaskets shall be of neoprene and shall be confined in a cored groove.

APPROVED MANUFACTURERS

American 2800-C

Mueller H-615

Schedule 17**VALVES, PRESSURE REGULATING**

Sizes - 3/4", 1", 1 1/2" and 2".

Pressure reducers to have spring range of 24 - 75 psi.

Pressure reducers are to be preset at 50 psi.

Shall have all bronze body and bell housing.

Shall have a built in by-pass to prevent buildup of excessive system pressure caused.

Shall be serviceable in-line.

Shall be Female Iron Pipe thread by Female Iron Pipe Thread (FIP x FIP).

APPROVED MANUFACTURERS

Watts

Wilkins

VALVES, GATE 2" (Ductile Iron Cast)

All gate valves must comply with the latest revision of AWWA Standard C-509/C-515 for Water Works Distribution Resilient Seat Valves.

All gate valves must have "O" Ring seals.

All gate valves must open left (counterclockwise) with 2" square operating wrench nut.

All gate valves should have a minimum working pressure of 200 psi and prior to shipment from the factory, each valve shall be tested by hydrostatic pressure equal to the requirements of ANSI/AWWA C-509/C-515 (and UL/FM where applicable).

All gate valves to be non-rising stem.

All 2" gate valves are to have threaded ends in accordance with ASME B16.4, Class 125.

The stem must be capable of being removed without disassembly of the valve and shall interchange with all valves of the same nominal pipe size, as produced by each representative manufacturer.

The valve shall be coated with an applied fusion-bonded epoxy coating in accordance with AWWA C-550 and be NSF 61 certified.

APPROVED MANUFACTURERS

- American Cast Iron Pipe
- Clow
- U. S. Pipe
- M & H Valve Company
- Mueller

VALVES, GATE 3" AND LARGER (Ductile Iron Cast)

All gate valves must comply with the latest revision of AWWA Standard C-509/C-515 for Water Works Distribution Resilient Seat Valves.

All gate valves must have "O" Ring seals.

All gate valves must open left (counterclockwise) with 2" square operating wrench nut.

All gate valves should have a minimum working pressure of 200 psi and prior to shipment from the factory, each valve shall be tested by hydrostatic pressure equal to the requirements of ANSI/AWWA C-509/C-515 (and UL/FM where applicable).

All gate valves to be non-rising stem.

All gate valves to have mechanical joint ends or flanged ends.

The stem must be capable of being removed without disassembly of the valve and shall interchange with all valves of the same nominal pipe size, as produced by each representative manufacturer.

The valve shall be coated with an applied fusion-bonded epoxy coating in accordance with AWWA C-550 and be NSF 61 certified.

APPROVED MANUFACTURERS

- American Cast Iron Pipe
- Clow
- U. S. Pipe

M & H Valve Company
Mueller

VALVES, TAPPING

All tapping valves shall comply with AWWA Specifications C-509 for resilient seat valves and the following design specifications.

All tapping valves are to be non-rising stem - open left.

Tapping valves 12 inch and smaller shall have a working pressure of 200 psig and tested at 400 psig and tap valves 14" and larger shall have a working pressure of 150 psig and test pressure of 300 psig.

All tapping valves shall be furnished with "O" Ring seals.

Tapping valves shall have an outlet end connection of the mechanical joint type. Inlet ends shall have an inlet flange for attaching to a sleeve or cross. A machine projection on this flange shall be made with a machined recess in the tapping sleeve outlet flange to assure correct alignment.

Seat opening of tapping valves shall be larger than the nominal size to permit full diameter cuts to be made.

All valves to have tap sleeve ends complete with bolts, glands and 1/8" thick rubber gaskets.

APPROVED MANUFACTURERS

American Cast Iron Pipe
Clow
U. S. Pipe
M & H Valve Company
Mueller

VALVE BOXES

Valve boxes shall be adjustable from 18" to 24" and 24" to 36".

Valve boxes shall be made from cast iron.

Valve boxes tops shall have the word "water" cast into the top.

The inside diameter shall be at least 5 1/4".

The adjustable top shall be the screw type.

The valve box top must have 2 slots for hooks to open top.

The bottom section must have a flair bottom to prevent settling.

Valve boxes shall be shipped fully assembled.

APPROVED MANUFACTURERS

Opelika Foundry #4905
Tyler-Union Foundry #6850
Bingham & Taylor #4905

Schedule 18

METER READING PRODUCTS

100W Water Communication ERT Module – ERW-1300-403

- Two “A” cell lithium batteries warranted for 20 years
- Maximum meter register pulse frequency: 4 Hertz
- Compatible with Sensus iPERL and Omni

100W Through the Lid Mount Kit – CFG-1300-004

- Compatible with the ERW-1300-403
- Compatible with a 2” hole through meter box lid

100W+ Through the Lid Antenna – CFG-0900-003

- TTL antenna American Disabilities Act compliant
- Compatible with the ERW-1300-403

Itron Splice Kit – OEM-0034-002

- Qty. 3 wire connectors
- 1 Gel Tube

5’ Cable with In-Line Connector with .167” Protective Coating – CFG-0151-010

- Itron connection X bare end wires (3 wires inside protective coating)

Schedule 19

INVERTED MARKING PAINT

Quik-Mark Solvent-Based Inverted Marking Paint

- Colors needed – Blue, Green, Red, Orange, Black, and White
- 17 OZ Cans

BID SUBMISSIONS WORK SHEETS

Line Item	Part Description	City Part ID	Unit	Bid Price
Schedule 1		Copper & Brass Pipe		
1.	3/4" COPPER PIPE TYPE K SOFT	WD0100	LF	
2.	1" COPPER PIPE TYPE K SOFT	WD0101	LF	
3.	2" RED BRASS PIPE (SEAMLESS) (12 FT. LONG)	WD0105	LF	
Schedule 2		Ductile Iron Pipe		
4.	4" CLASS 350 - D. I. PIPE	WD0131	LF	
5.	6" CLASS 350 - D. I. PIPE	WD0132	LF	
6.	8" CLASS 350 - D. I. PIPE	WD0133	LF	
7.	12" CLASS 350 - D. I. PIPE	WD0125	LF	
8.	24" CLASS 250 - D. I. PIPE	WD0128	LF	
Schedule 3		HDPE Pipe		
9.	15" HDPE PIPE	WD3612	LF	
10.	18" HDPE PIPE	WD3613	LF	
11.	24" HDPE PIPE	WD3614	LF	
12.	30" HDPE PIPE	WD3615	LF	
13.	36" HDPE PIPE	WD3616	LF	
Schedule 4		Galvanized Pipe		
14.	3/4" GALV. PIPE (T & C) (10 FT. Long)	WD0107	LF	
15.	1" GALV. PIPE (T & C) (10 FT. LONG)	WD0108	LF	
16.	1 1/2" GALV. PIPE (T & C) (10 FT. LONG)	WD0110	LF	
17.	2" GALV. PIPE (T & C) (10 FT. LONG)	WD0111	LF	
Schedule 5		Fire Hydrants and Accessories		
18.	FIRE HYDRANTS (SPECIFY BRAND AND MODEL) M. J. 3 FT. BURY	WD1900	EACH	
19.	FIRE HYDRANTS (SPECIFY BRAND AND MODEL) M. J. 3 FT 6 IN BURY	WD3269	EACH	
20.	FIRE HYDRANTS (SPECIFY BRAND AND MODEL) M. J. 4 FT. BURY	WD1901	EACH	
21.	FIRE HYDRANTS (SPECIFY BRAND AND MODEL) M. J. 5 FT. BURY	WD1902	EACH	
Schedule 6		Manhole Rings, Covers, Risers and Accessories		
22.	MANHOLE RING, STANDARD V1344	WD7075	EACH	
23.	MANHOLE COVER, LOGO STANDARD AND LOW PROFILE (V1344-1)	WD7156	EACH	
24.	MANHOLE ADJUSTMENT RING 3"	WD7080	EACH	
25.	MANHOLE ADJUSTMENT RING 4"	WD7081	EACH	
26.	MANHOLE ECCENTRIC CONE TOP 48" X 36"	WD7091	EACH	
27.	MANHOLE BAR (KEN-TOOL#33223)	WD7151	EACH	
28.	1" ORLANDO RISER RING (23-2-1)	WD7155	EACH	
Schedule 7		Meter Accessories		
29.	3/4" COMP X FIP CURB STOP MCDONALD 6102WT OR EQUAL	WD1700	EACH	
30.	3/4" COPPER FLARE X F.I.P. CURB STOPS MCDONALD 76102W OR EQUAL	WD1731	EACH	
31.	3/4" FIP X FIP CURB STOP MCDONALD 6101W OR EQUAL	WD1701	EACH	
32.	1" COMP X FIP CURB STOPS MCDONALD 6102WT OR EQUAL	WD1702	EACH	
33.	1" FIP X FIP CURB STOPS MCDONALD 6101W OR EQUAL	WD1703	EACH	
34.	2" FIP X FIP CURB STOP MCDONALD 6101W OR EQUAL	WD1704	EACH	
35.	3/4" CORPORATION STOPS MCDONALD 74701BT OR EQUAL	WD1710	EACH	
36.	1" CORPORATION STOPS MCDONALD 4701T OR EQUAL	WD1711	EACH	

BID NO. 9070-083021-1

Signature _____

Line Item	Part Description	City Part ID	Unit	Bid Price
37.	3/4" METER COUPLINGS 1 1/2" LONG	WD1714	EACH	
38.	3/4" METER COUPLINGS 2" LONG	WD1715	EACH	
39.	3/4" METER COUPLINGS 2 1/2" LONG	WD1716	EACH	
40.	3/4" METER COUPLING 2 3/4" LONG	WD1717	EACH	
41.	1" METER COUPLINGS 2 1/2" LONG	WD1720	EACH	
42.	1" METER COUPLINGS 1 1/2" LONG	WD1719	EACH	
43.	3/4" X 1/8" RUBBER METER WASHER	WD3230	EACH	
44.	3/4" X 1/16" RUBBER METER WASHER	WD1741	EACH	
45.	3/4" X 1/32" RUBBER METER WASHER	WD3557	EACH	
46.	1" X 1/8 RUBBER METER WASHER	WD3675	EACH	
47.	1" X 1/16 RUBBER METER WASHER	WD3676	EACH	
48.	3/4" X 1/16" FIBER METER WASHER	WD1739	EACH	
49.	3/4" X 1/32" FIBER METER WASHER	WD1740	EACH	
50.	1" X 1/16" FIBER METER WASHER	WD1743	EACH	
51.	1" X 1/32" FIBER METER WASHER	WD1744	EACH	
52.	2' X 3' X 30" METER VAULT	WD1762	EACH	
53.	3 X 5 X 36" METER VAULT	WD1766	EACH	
54.	4 X 6 X 48" METER VAULT (927 LB BODY,391 LB FOR LIDS)	WD1768	EACH	
55.	STANDARD PLASTIC METER BOX (10"X15"X10") (BOX ONLY)	WD1772	EACH	
56.	STANDARD METER BOX LID (SOLID) LC-528	WD3728	EACH	
57.	STANDARD METER BOX LID (WITH 2" HOLE) LC-528T	WD3729	EACH	
58.	STANDARD PLASTIC METER BOX LID (WITH 2" HOLE) D1200-DITRL	TBD	EACH	
59.	JUMBO PLASTIC METER BOX (13"X20"X12") (BOX ONLY)	WD1773	EACH	
60.	JUMBO METER BOX LID (SOLID) LC-2115	WD3726	EACH	
61.	JUMBO METER BOX LID (WITH 2" HOLE) LC-2115T	WD3727	EACH	
62.	JUMBO PLASTIC METER BOX LID (WITH 2" HOLE) D1500-DISBTRLD	TBD	EACH	
63.	MSP STANDARD 11" X 18" X 12" METER BOX & LID	WD3208	EACH	
64.	MSP JUMBO 13" X 24" X 12" METER BOX & LID	WD3232	EACH	
65.	3/4" WILKINS #700 (FIP X FIP) BACKFLOW PREVENTERS OR EQUAL	WD1774	EACH	
66.	1" WILKINS #700 (FIP X FIP) BACKFLOW PREVENTERS OR EQUAL	WD1775	EACH	
67.	1 1/2" BACKFLOW PREVENTER(WATTS 007QT 16 3/4" LONG)	WD3049	EACH	
68.	2" WILKINS #950 BACKFLOW PREVENTERS OR EQUAL (19 1/2" LONG)	WD1776	EACH	
69.	2" BRONZE METER FLANGES WITH BOLTS & GASKETS	WD0845	EACH	
70.	1 1/2" BRONZE METER FLANGES WITH BOLTS & GASKETS	WD0844	EACH	
71.	1-1/2" FULL FACE METER GASKET	WD3553	EACH	
72.	2" FULL FACE METER GASKET	WD3554		
73.	HAND PUMP (METER BOX)	WD3555		
Schedule 8		Water Meters		
Meters with Standard Cable				
74.	3/4" SHORT ELECTROMAGNETIC WATER METER	WD1747	EACH	
75.	3/4" ELECTROMAGNETIC WATER METER	WD1748	EACH	
76.	1" ELECTROMAGNETIC WATER METER	WD1749	EACH	
77.	1 1/2" RESIDENTIAL WATER METERS, CU. FT.	WD1750	EACH	
78.	1 1/2" COMPOUND WATER METER, CU. FT. (13" long)	WD3438	EACH	

BID NO. 9070-083021-1

Signature _____

Line Item	Part Description	City Part ID	Unit	Bid Price
79.	2" COMPOUND WATER METERS, CU. FT. (15 1/4" long)	WD3283	EACH	
80.	2" RESIDENTIAL WATER METERS, CU. FT.	WD1751	EACH	
81.	3" COMPOUND WATER METERS, CU. FT. (17" long)	WD1752	EACH	
82.	4" COMPOUND WATER METERS, CU. FT. (20" long)	WD1754	EACH	
	Meters with ITRON Cable			
83.	3/4" SHORT ELECTROMAGNETIC WATER METER	TBD	EACH	
84.	3/4" ELECTROMAGNETIC WATER METER	TBD	EACH	
85.	1" ELECTROMAGNETIC WATER METER	TBD	EACH	
86.	1 1/2" RESIDENTIAL WATER METERS, CU. FT.	TBD	EACH	
87.	1 1/2" COMPOUND WATER METER, CU. FT. (13" long)	TBD	EACH	
88.	2" COMPOUND WATER METERS, CU. FT. (15 1/4" long)	TBD	EACH	
89.	2" RESIDENTIAL WATER METERS, CU. FT.	TBD	EACH	
90.	3" COMPOUND WATER METERS, CU. FT. (17" long)	TBD	EACH	
91.	4" COMPOUND WATER METERS, CU. FT. (20" long)	TBD	EACH	
92.	6" COMPOUND WATER METERS, CU. FT. (24" long)	TBD	EACH	
	Hydrant Meter			
93.	SENSUS OMNI H2 HYDRANT METER, H3X2HX1FXAXX1ND - OR EQUAL	TBD	EACH	
	Schedule 9 2" and Smaller Pipe Accessories			
94.	1/2" X 2" BRASS NIPPLES	WD1348	EACH	
95.	1/2" X 4" BRASS NIPPLES	WD1349	EACH	
96.	1/2" X 6" BRASS NIPPLES	WD1350	EACH	
97.	3/4" CLOSE BRASS NIPPLE	WD3276	EACH	
98.	3/4" X 2" BRASS NIPPLES	WD1351	EACH	
99.	3/4" X4" BRASS NIPPLES	WD1352	EACH	
100.	3/4" X 6" BRASS NIPPLES	WD1353	EACH	
101.	1" X CLOSE BRASS NIPPLE	WD3233	EACH	
102.	1" X 2" BRASS NIPPLES	WD1354	EACH	
103.	1" X 4" BRASS NIPPLES	WD1355	EACH	
104.	1" X 6" BRASS NIPPLES	WD1356	EACH	
105.	1 1/2" X 12" BRASS NIPPLES	WD3437	EACH	
106.	2" X 2 1/2" BRASS NIPPLES	WD1366	EACH	
107.	2" X 4" BRASS NIPPLES	WD1367	EACH	
108.	2" X 6" BRASS NIPPLES	WD1368	EACH	
109.	2" X 8" BRASS NIPPLES	WD1369	EACH	
110.	2" X 12" BRASS NIPPLES	WD1370	EACH	
111.	3/4" BRASS HAYSTITE NUT (CAMBRIDGE BRASS 81-J3)	WD3057	EACH	
112.	1" BRASS HAYSTITE NUT (CAMBRIDGE BRASS 81-J4)	WD3058	EACH	
113.	2" UNIFLANGE 1300-S (RESTRAINT DEVICE)	WD3160	EACH	
114.	3/4" X 3 1/2" LONG T-HEAD BOLT WITH HEAVY HEX NUT	WD0819	EACH	
115.	3/4" X 4" LONG T-HEAD BOLT WITH HEAVY HEX NUT	WD0820	EACH	
116.	3/4" X 4 1/2" LONG T-HEAD BOLT WITH HEAVY HEX NUT	WD0821	EACH	
117.	3/4" X 3/4" XS LEAD X MALE COMP COUP (M74753-67)	WD3539	EACH	
118.	3/4" BRASS PLUG	WD1301	EACH	
119.	1" BRASS PLUG	WD1302	EACH	

BID NO. 9070-083021-1

Signature _____

Line Item	Part Description	City Part ID	Unit	Bid Price
120.	2" BRASS PLUGS	WD1305	EACH	
121.	3/4" BRASS CAPS	WD1308	EACH	
122.	1" BRASS CAPS	WD1309	EACH	
123.	2" BRASS CAPS	WD1312	EACH	
124.	3/4" X 1/2" BRASS BUSHINGS	WD1313	EACH	
125.	1" X 3/4" BRASS BUSHINGS	WD1315	EACH	
126.	1" X 3/4" BRASS REDUCERS	WD1332	EACH	
127.	3/4" BRASS 90 DEGREE ELLS	WD1397	EACH	
128.	1" BRASS 90 DEGREE ELLS	WD1398	EACH	
129.	1 1/2" BRASS 90 DEGREE ELLS	WD1400	EACH	
130.	2" BRASS 90 DEGREE ELLS	WD1401	EACH	
131.	3/4" BRASS 45 DEGREE ELLS	WD3682	EACH	
132.	1" BRASS 45 DEGREE ELLS	WD3683	EACH	
133.	2" BRASS 45 DEGREE ELLS	WD1417	EACH	
134.	3/4" BRASS TEES	WD1421	EACH	
135.	1" BRASS TEES	WD1423	EACH	
136.	2" X 3/4" BRASS TEES	WD1436	EACH	
137.	2" X 1" BRASS TEES	WD1437	EACH	
138.	2" X 2" BRASS TEES	WD1440	EACH	
139.	1/2" BRASS COUPLINGS	WD1447	EACH	
140.	3/4" BRASS COUPLINGS	WD1448	EACH	
141.	1" BRASS COUPLINGS	WD1449	EACH	
142.	1 1/2" BRASS COUPLINGS	WD1451	EACH	
143.	2" BRASS COUPLINGS	WD1452	EACH	
144.	2" BRASS UNION	WD1460	EACH	
145.	3/4" SPIGOTS, ARROWHEAD OR EQUAL	WD1707	EACH	
146.	3/4" MALE ADAPTERS MCDONALD 4753T OR EQUAL	WD1708	EACH	
147.	3/4" FEMALE ADAPTERS MCDONALD 4754T OR EQUAL	WD1709	EACH	
148.	1" MALE ADAPTERS MCDONALD 4753T OR EQUAL	WD1722	EACH	
149.	1" FEMALE ADAPTERS MCDONALD 4754T OR EQUAL	WD1723	EACH	
150.	3/4" 3-PART UNIONS MCDONALD 4758T OR EQUAL	WD1724	EACH	
151.	1" 3-PART UNIONS MCDONALD 4758T OR EQUAL	WD1725	EACH	
152.	1" X 1" X 1" COPPER COMPRESSION TEES MCDONALD 4760T OR EQUAL	WD1726	EACH	
153.	1" X 3/4" X 3/4" U-BRANCH MCDONALD 708UQM	WD1727	EACH	
154.	1" X 3/4" BRASS COMPRESSION WYES MCDONALD 708YSTT OR EQUAL	WD1728	EACH	
155.	3/4" COMP. X M.I.P. 90 DEGREE BENDS MCDONALD 4779MT OR EQUAL	WD1729	EACH	
156.	1" COMP. X M.I.P. 90 DEGREE BENDS MCDONALD 4779MT OR EQUAL	WD1730	EACH	
157.	3/4" BRASS COMPRESSION TEES MCDONALD 4760T OR EQUAL	WD1733	EACH	
158.	3/4" X 6" BOLTS FOR UNIVERSAL PIPE	WD3195	EACH	
159.	3/4"-1 1/4" CHINESE FINGERS GRIP (PART # 185-903)	WD3240	EACH	
160.	1 1/2" MCDONALD BY PASS ASSEMBLY	WD3302	EACH	
161.	2" MCDONALD METER BYPASS (36" LONG)	WD3303	EACH	
	Schedule 10	3" and Larger Pipe Accessories		
162.	6" FOSTER ADPT & ACCESS	WD3346	EACH	

BID NO. 9070-083021-1

Signature _____

Line Item	Part Description	City Part ID	Unit	Bid Price
163.	6" RUN X 4" BRANCH M. J. TEES	WD0201	EACH	
164.	6" RUN X 6" BRANCH M. J. TEES	WD0202	EACH	
165.	8" RUN X 6" BRANCH M. J. TEES	WD0204	EACH	
166.	8" X 6" CONCENTRIC M. J. REDUCERS	WD0242	EACH	
167.	6" 90 DEGREE MECHANICAL JOINT BEND	WD0333	EACH	
168.	8" 90 DEGREE MECHANICAL JOINT BEND	WD0334	EACH	
169.	4" 45 DEGREE MECHANICAL JOINT BEND	WD0341	EACH	
170.	6" 45 DEGREE MECHANICAL JOINT BEND	WD0342	EACH	
171.	6" 22 1/2 DEGREE MECHANICAL JOINT BEND	WD0351	EACH	
172.	8" 22 1/2 DEGREE MECHANICAL JOINT BEND	WD0352	EACH	
173.	4" MJ PLUG WITH 2" IPT TAP	WD0372	EACH	
174.	8" MJ PLUG WITH 2" IPT TAP	WD0374	EACH	
175.	12" MJ CAP WITH 2" IPT TAP	WD0392	EACH	
176.	6" SOLID M.J. SLEEVES	WD0538	EACH	
177.	8" SOLID M.J. SLEEVES	WD0539	EACH	
178.	12" SOLID M.J. SLEEVES	WD0540	EACH	
179.	4" X 12" ANCHOR COUPLINGS, DUCTILE IRON	WD0368	EACH	
180.	6" X 12" ANCHOR COUPLINGS, DUCTILE IRON	WD0369	EACH	
181.	8" X 12" ANCHOR COUPLINGS, DUCTILE IRON	WD0370	EACH	
182.	4" RUN X 4" BRANCH FLANGED TEES	WD0396	EACH	
183.	4" 90 DEGREE FLANGED BEND	WD0493	EACH	
184.	3" 90 DEGREE FLANGED BEND	WD3404	EACH	
185.	3" RUN X 3" BRANCHED FLANGED TEE	WD3405	EACH	
186.	4" M.J. X 3" FLANGED REDUCER	WD3407	EACH	
187.	3" MJFA-3-I FLANGE COUPLING ADAPTER	WD3408	EACH	
188.	4" MJFA-4-I FLANGE COUPLING ADAPTER	WD1003	EACH	
189.	6" MJFA-6-I FLANGE COUPLING ADAPTER	WD1004	EACH	
190.	3" X 12" FLANGE X PE SPOOL	WD3410	EACH	
191.	3" x 12" FLANGE X FLANGE SPOOL	WD3435	EACH	
192.	3" X 24" FLANGE X FLANGE SPOOL	WD3411	EACH	
193.	3" X 36" FLANGE X FLANGE SPOOL	WD3412	EACH	
194.	4" X 12" FLANGE X FLANGE SPOOL	WD3077	EACH	
195.	4" X 24" FLANGE X FLANGE SPOOL	WD3218	EACH	
196.	4" X 48" FLANGED X FLANGED SPOOL	WD3464	EACH	
197.	4" X 36" FLANGE X FLANGE SPOOL	WD3287	EACH	
198.	6" X 36" LONG FLANGE X FLANGE SPOOL	WD3074	EACH	
199.	4" UNIFLANGE 1300-C (RESTRAINT DEVICE)	WD3161	EACH	
200.	6" UNIFLANGE 1300-C (RESTRAINT DEVICE)	WD3162	EACH	
201.	8" UNIFLANGE 1300-C (RESTRAINT DEVICE)	WD3163	EACH	
202.	12" UNIFLANGE 1300-C (RESTRAINT DEVICE)	WD3165	EACH	
203.	3" FLANGE PACKS (NUTS, BOLTS, GASKETS)	WD3406	EACH	
204.	4" FLANGE PACK (BOLTS, NUTS, GASKET)	WD0800	EACH	
205.	6" FLANGE PACK (BOLTS, NUTS, GASKET)	WD0801	EACH	
206.	4" MJ GASKET FOR 4" NOMINAL DIAMETER FITTINGS	WD0828	EACH	

BID NO. 9070-083021-1

Signature _____

Line Item	Part Description	City Part ID	Unit	Bid Price
207.	6" MJ GASKET FOR 6" NOMINAL DIAMETER FITTINGS	WD0829	EACH	
208.	8" MJ GASKET FOR 8" NOMINAL DIAMETER FITTINGS	WD0830	EACH	
209.	12" MJ GASKET FOR 12" NOMINAL DIAMETER FITTINGS	WD0832	EACH	
210.	4" MEGALUG RESTRAINED GLAND, DUCTILE IRON	WD0643	EACH	
211.	6" MEGALUG RESTRAINED GLAND, DUCTILE IRON	WD0644	EACH	
212.	8" MEGALUG RESTRAINED GLAND, DUCTILE IRON	WD0645	EACH	
213.	10 " MEGALUG RESTRAINED GLAND, DUCTILE IRON	WD3242	EACH	
214.	12" MEGALUG RESTRAINED GLAND, DUCTILE IRON	WD0646	EACH	
215.	16" MEGALUG RESTRAINED GLAND, DUCTILE IRON	WD0647	EACH	
Schedule 11		Pipe Accessories		
216.	PIPE LUBRICANT - 1 QUART CONTAINERS	WD2001	EACH	
217.	PIPE LUBRICANT - 1 GALLON CONTAINERS	WD2002	EACH	
218.	JOMAR PIPE LUBRICANT (GREEN STUFF) - PINT CONTAINERS	WD2003	EACH	
219.	WATER LINE MARKERS (6x2 1/2") CARSONITE OR EQUAL	WD2004	EACH	
220.	LOCATING WIRE (14 GUAGE SOLID COPPER)	WD3211	EACH	
221.	DUCTILE LUGS DUCTILE IRON (MEETING ASTM A536-80)	WD0823	EACH	
222.	3/4" ALL THREAD ROD	WD3032	EACH	
223.	PROBING RODS	WD3011	EACH	
Schedule 12		Dresser Couplings		
224.	2" HYMAX DRESSER COUPLING FOR 2" OR 2 1/2" COPPER (PART # 2000-0303-260)	WD3426	EACH	
225.	3" HYMAX DRESSER COUPLING COPPER PART# 2000-0433-260	WD3424	EACH	
226.	4" HYMAX DRESSER COUPLING RANGE (4.25-5.63)	WD3484	EACH	
227.	6" HYMAX DRESSER COUPLING (O.D. 6.42-7.68)	WD3489	EACH	
228.	8" HYMAX DRESSER COUPLING (OD 8.54-9.84)	WD3488	EACH	
229.	1/2" BRASS PACK JOINT COUPLING (C77-XX-NL OR EQUAL)	WD4000	EACH	
230.	3/4" BRASS PACK JOINT COUPLING (C77-XX-NL OR EQUAL)	WD4001	EACH	
231.	1" BRASS PACK JOINT COUPLING (C77-XX-NL OR EQUAL)	WD4002	EACH	
232.	1 1/4" BRASS PACK JOINT COUPLING (C77-XX-NL OR EQUAL)	WD4003	EACH	
233.	1 1/2" BRASS PACK JOINT COUPLING (C77-XX-NL OR EQUAL)	WD4004	EACH	
234.	2" BRASS PACK JOINT COUPLING (C77-XX-NL OR EQUAL)	WD4005	EACH	
235.	3/4" BRASS RANGER COUPLING (74758-11)	WD4009	EACH	
236.	1" BRASS RANGER COUPLING (74758-11)	WD4010	EACH	
Schedule 13		Repair Clamps		
237.	2" X 7-1/2" FULL CIRCLE REPAIR CLAMP (F1-263-75)	WD3342	EACH	
238.	1/2" X 3" HANDIBAND REPAIR CLAMP FOR STEEL (Snap)	WD0951	EACH	
239.	1/2" X 6" HANDIBAND REPAIR CLAMP FOR STEEL (Snap)	WD0952	EACH	
240.	3/4" X 3" HANDIBAND REPAIR CLAMP FOR STEEL (Snap)	WD0953	EACH	
241.	3/4" X 6" HANDIBAND REPAIR CLAMP FOR STEEL (Snap)	WD0954	EACH	
242.	1" X 3" HANDIBAND REPAIR CLAMP FOR STEEL (Snap)	WD0955	EACH	
243.	1" X 6" HANDIBAND REPAIR CLAMP FOR STEEL (Snap)	WD0956	EACH	
244.	2" X 3" HANDIBAND REPAIR CLAMP (Snap)	WD0961	EACH	
245.	2" X 6" HANDIBAND REPAIR CLAMP (Snap)	WD0962	EACH	
246.	2" x 7.50" COLLAR LEAK REPAIR CLAMP	WD3178	EACH	
247.	1 1/2" X 3" WRAP CLAMP REPAIR CLAMP (FSC-190-3R)	WD3503	EACH	

BID NO. 9070-083021-1

Signature _____

Line Item	Part Description	City Part ID	Unit	Bid Price
248.	1 1/4" X 3" WRAP CLAMP REPAIR CLAMP	WD3504	EACH	
249.	2" X 3" WRAP REPAIR CLAMP	WD3509	EACH	
250.	2" X 6" WRAP REPAIR CLAMP	WD3510	EACH	
	Schedule 14 PVC Pipe			
251.	2" PVC PIPE, CLASS 200	WD0115	LF	
252.	4" SCHEDULE 40 PVC PIPE	WD7001	LF	
253.	6" PVC PIPE, CLASS 200	WD0118	LF	
254.	12" SCHEDULE 40 PVC PIPE	WD7005	LF	
255.	12" PVC HW SEWER PIPE 14LF	WD7062	LF	
	Schedule 15 Sewer Pipe Accessories & Related Items			
256.	4" CLAY TO PVC FERNCO SHEAR COUPLING	WD7063	EACH	
257.	6" CLAY TO PVC FERNCO SHEAR COUPLING	WD7064	EACH	
258.	4" PVC TO PVC FERNCO SHEAR COUPLING	WD7069	EACH	
259.	8" PVC TO PVC FERNCO SHEAR COUPLING	WD7071	EACH	
260.	SANITARY SEWER MANHOLE MARKERS (WHITE)	WD7021	EACH	
261.	FULL RANGE 3M MARKER WASTE WATER	WD7053	EACH	
262.	4" SDR-26 HW SEWER PIPE 14LF	WD7058	EACH	
263.	6" SDR-26 HW SEWER PIPE 14LF	WD7059	EACH	
264.	8" SDR-26 HW SEWER PIPE 14LF	WD7060	EACH	
265.	10" SDR-26 HW SEWER PIPE 14LF	WD7061	EACH	
266.	4" PVC HW SEWER SXG ST 22 DEG BEND	WD7089	EACH	
267.	8" CL-350 DI PERMOX LINED	WD7150	EACH	
268.	10" CL-350 PERMOX LINED DI PIPE	WD7092	EACH	
269.	16" DI PIPE W/PERMOX LINING	WD7120	EACH	
270.	TIGER TAIL 3" x 36"	WD7123	EACH	
271.	2" SEWER AIR RELEASE VALVE (ARV) APCO MN:402WA.1	WD7087	EACH	
272.	2" SEWER ARV (CRISPIN MN: SL20) W/BACKFLUSH VALVE	WD7125	EACH	
273.	2" STAINLESS ARV (CRISPIN - UX, D434G00UX20)	WD3656	EACH	
274.	4" GRIPPER PLUG (WING NUT)	WD7134	EACH	
275.	4" PVC SEWER SOLVENT WELD END CAP (SDR-35)	WD7050	EACH	
276.	WATER PLUG (50 LB PAILS)	WD7023	EACH	
277.	16" MJ SOLID SLEEVE PERMOX LINED	WD7138	EACH	
	Schedule 16 Tap Sleeves & Saddles			
278.	2" X 3/4" BRONZE SADDLES, CC THREAD FOR PVC PIPE (MCDONALD 3892)	WD1606	EACH	
279.	2" X 1" BRONZE SADDLES, CC THREAD FOR PVC PIPE (MCDONALD 3892)	WD1607	EACH	
280.	3" X 3/4" BRONZE TAP SADDLE FOR PVC	WD3466	EACH	
281.	4" X 2" TAP SADDLES, I.P.T. DOUBLE STRAP FOR C.I. 4.76 - 5.26	WD1612	EACH	
282.	6" X 1" TAP SADDLES, CC THREAD, DOUBLE STRAP PVC 6.63 - 6.90	WD1626	EACH	
283.	6" X 2" TAP SADDLES, I.P.T. DOUBLE STRAP, FOR DI 6.84 - 7.60	WD1613	EACH	
284.	8" X 2" TAP SADDLES, I.P.T. DOUBLE STRAP, FOR C.I. PIPE 8.99 - 9.79	WD1614	EACH	
285.	12" X 2" TAP SADDLES, I.P.T. DOUBLE STRAP, FOR C.I. PIPE	WD1616	EACH	
286.	16" X 2" TAP SADDLES, I.P.T. DOUBLE STRAP, FOR C.I. PIPE	WD1618	EACH	
287.	6" X 6" SS TAP SLEEVE (JCM #432 OR EQUAL)(OD 7.05 -7.40)	WD3351	EACH	
288.	6" X 6" SS TAP SLEEVE DI (JCM #432 OR EQUAL)(O.D. 6.83-7.16)	WD3383	EACH	

BID NO. 9070-083021-1

Signature _____

Line Item	Part Description	City Part ID	Unit	Bid Price
289.	8" X 8" SS TAP SLEEVE (JCM #432 OR EQUAL) (OD 8.98-9.37)	WD3354	EACH	
290.	12" X 8" TAP SLEEVE (AMERICAN #AFC-2800 OR EQUAL)	WD0611	EACH	
	Schedule 17	Valves & Accessories		
291.	2" STOCKHAM B103 GATE VALVES OR EQUAL	WD1805	EACH	
292.	2" RS THREADED GATE VALVE	WD3462	EACH	
293.	4" TAPPING VALVES (AMERICAN 2500 RS OR EQUAL)	WD0734	EACH	
294.	6" TAPPING VALVES (AMERICAN 2500 RS OR EQUAL)	WD0735	EACH	
295.	8" TAPPING VALVES (AMERICAN 2500 RS OR EQUAL)	WD0736	EACH	
296.	4" GATE VALVES - (M.J.) (AMERICAN 2500 RS OR EQUAL)	WD0710	EACH	
297.	6" GATE VALVES - (M.J.) (AMERICAN 2500 RS OR EQUAL)	WD0711	EACH	
298.	8" GATE VALVES - (M.J.) (AMERICAN 2500 RS OR EQUAL)	WD0712	EACH	
299.	3" GATE VALVES (FLANGED) (AMERICAN 865 RS OR EQUAL)	WD3414	EACH	
300.	4" GATE VALVES (FLANGED) (AMERICAN 2500 RS OR EQUAL)	WD0724	EACH	
301.	3/4" PRESSURE REDUCER VALVES WILKINS #600 OR EQUAL	WD1816	EACH	
302.	1" PRESSURE REDUCER VALVES WILKINS #600 OR EQUAL	WD1817	EACH	
303.	1 1/2" PRESSURE REDUCER VALVES WILKINS #600 OR EQUAL	WD1818	EACH	
304.	2" PRESSURE REDUCER VALVES WILKINS #600 OR EQUAL	WD1819	EACH	
305.	2" VALVE BOX RISERS FOR 7" VALVE BOX	WD0764	EACH	
306.	2" STOCKHAM B-319 CHECK VALVE OR EQUAL	WD1812	EACH	
307.	VALVE BOX, 18" X 24" SCREW TYPE W/LID (5-1/4" DIA.)	WD0757	EACH	
308.	1" ADAPTERS FOR 5 1/4" VALVE BOXES	WD0759	EACH	
309.	1 1/2" ADAPTERS FOR 5 1/4" VALVE BOXES	WD0760	EACH	
310.	6" X 5 1/4" VALVE BOX RISER	WD3431	EACH	
311.	5 1/4" VALVE BOX WATER LID ONLY	WD3439	EACH	
	Schedule 18	New Meter Reading Products		
312.	ENCODER WITH INTEGRAL CONNECTOR AND LEAK SENSOR ERW-1300-403	WD4106	EACH	
313.	100W THROUGH THE LID MOUNT KIT CFG-1300-004	WD4107	EACH	
314.	THROUGH THE LID REMOTE MOUNT ANTENNA KIT CFG-0900-003	TBD	EACH	
315.	ITRON SPLICE KIT OEM-0034-002	WD4108	EACH	
316.	5' CABLE WITH IN-LINE CONNECTOR WITH .167" PROTECTIVE COVER CFG-0151-010	WD4109	EACH	
	Schedule 19	Locating Products		
317.	BLUE INVERTED MARKING PAINT (KRYLON INDUSTRIAL QUIK MARK)	WD2000	EACH	
318.	GREEN INVERTED MARKING PAINT (KRYLON INDUSTRIAL QUIK MARK)	WD7000	EACH	
319.	WHITE INVERTED MARKING PAINT (KRYLON INDUSTRIAL QUIK MARK)	WD3598	EACH	
320.	RED INVERTED MARKING PAINT (KRYLON INDUSTRIAL QUIK MARK)	WD4120	EACH	
321.	ORANGE INVERTED MARKING PAINT (KRYLON INDUSTRIAL QUIK MARK)	WD4121	EACH	

BIDDER'S RESPONSE FORM

MESSAGE TO BIDDERS: Please review your bid documents for accuracy, completeness, required documentation, and necessary signatures before submitting. Please label the outer mailing/shipping package with the bid information as directed.

COMPANY NAME: _____

CONTACT PERSON: _____

COMPLETE MAILING ADDRESS: _____

AUTHORIZED SIGNATURE: _____

PRINTED NAME: _____

TELEPHONE NUMBER: _____

E-MAIL ADDRESS: _____

COPIES SUBMITTED:

_____ **VENDOR MUST SUBMIT AN ORIGINAL BID AND ONE COMPLETE COPY OR THE BID MAY BE REJECTED.**

Awarded bidder(s) may be required to obtain a City of Tuscaloosa business license in order to provide goods and/or services in response to this bid and subsequent contract(s). Inquiries regarding business license requirements should be directed to the City's Revenue & Financial Services Division at (205) 248-5200. Failure to obtain and maintain required city business license(s) may result in rescinding of bid award and contract termination.

Note: By signing this contract, the contracting parties affirm, for the duration of the agreement, that they will not violate federal immigration law or knowingly employ, hire for employment, or continue to employ an unauthorized alien within the State of Alabama. Furthermore, a contracting party found to be in violation of this provision shall be deemed in breach of the agreement and shall be responsible for all damages resulting therefrom.

FAILURE TO COMPLETE ALL OF THE ABOVE WITH AN AUTHORIZED SIGNATURE MAY SUBJECT BID TO REJECTION.