



ADDENDUM NO. 3

Date: January 7, 2015

Project: City of Tuscaloosa
Cedar Crest Drainage Structure Project
Project No. A13-0580

Bid Date: **Thursday, January 8, 2015**
2:00 p.m. local time
City Council Chambers in City Hall

The following changes, additions, clarifications, and/or deletions are hereby made part of the Contract Documents for the project referenced above as fully and completely as if the same were set forth fully therein:

1. Bidder Questions:

- a. Question: Reference Drawing C6.1 Typical Alley and Box Culvert Detail. How are we to be paid for any undercut of unsuitable material below the proposed culvert bedding, legend number 10, elevations?

Answer: The material below the bedding (below legend number 10) is trench foundation. If this material is required, McGiffert and Associates, LLC representatives and/or the geotechnical representative will be the ones to make that determination. If this material is required, the removal of the unsuitable material and the replacement of the foundation material will be paid for in line item # 314.

END OF ADDENDUM NO. 3



RECEIPT OF ADDENDUM NO. 3

Project: City of Tuscaloosa
Cedar Crest Drainage Structure Project
Project No. A13-0580

The following hereby acknowledges receipt of Addendum No. 3, dated January 7, 2015.

Complete the following and return by fax to (205) 759-1524 or scan and email to dmarcum@mcgiffert.com.

We are in receipt of Addendum No. 2 and fully understand the contents and our bid on the above referenced project submitted reflects the intent of this Addendum.

Contractor Name

*By: _____

Date: _____

* *Signature must be by person legally qualified to sign bid.*